



State of Ohio Environmental Protection Agency

STREET ADDRESS:

W. Lazarus Government Center
50 W. Town St., Suite 700
Columbus, Ohio 43215

Central District Office

TELE: (614) 728-3778 FAX: (614) 728-3898
www.epa.state.oh.us

MAILING ADDRESS:

P.O. Box 1049
Columbus, OH 43216-1049

July 29, 2010

Miriam Siegfried
City of Columbus DOPU, DOPW
910 Dublin Road
Columbus, OH 43215

**Re: Construction Storm Water Inspection at Production Well C-120
Franklin County.
Permit Number: 4GC02919*AG**

Dear Ms. Siegfried:

This letter is written regarding the storm water inspection conducted by Vinod Tujalpuram and Abigail Tamkin of Ohio EPA at Production Well C-120 located at 5414 Parsons Avenue Columbus, Ohio on July 27, 2010. The Agency understands that these construction activities are currently covered under the General Storm Water Permit Associated with Construction Activities. Based on the site inspection and the General Storm Water Permit, the following items were noted;

Sediment and Erosion Controls:

- The Silt fence along the perimeter of the project, adjacent to the farm land will require maintenance at this time.
- The silt fence located on the east end of the pond must be re-established to minimize sediment transport offsite.

Maintenance

- The sediment controls implemented on this site will require maintenance or reinstallation to ensure a proper functioning condition. This general permit states that all sediment controls will be inspected and maintained every seven days or within 24 hours of a precipitation event equal to or greater than 0.5 inches. A log of inspection must be maintained on-site for the agency to review.


Ted Strickland, Governor
Lee Fisher, Lieutenant Governor
Chris Korleski, Director

Post Construction Requirements:

- The General Storm Water Permit requires specific post construction water quality treatment for all sites. Guidance regarding the post construction requirements is found at: <http://www.epa.state.oh.us/dsw/storm/CGPPCQA.aspx>. Please submit to my attention (email preferred at harry.kallipolitis@epa.state.oh.us) which practice will be installed at this site to ensure compliance with the General Permit. Please include all design criteria and calculations in your submission

If you have any questions regarding this letter or the inspection, please do not hesitate to call me at our Central District Office at (614) 728-3844 or email at harry.kallipolitis@epa.state.oh.us. A follow up inspection will be conducted to ensure the conditions of the General Permit are met.

Sincerely,



Harry Kallipolitis
Storm Water Coordinator
Division of Surface Water
Central District Office

c: Jeff Bohne, Water Quality Supervisor, DSW/CDO