



State of Ohio Environmental Protection Agency

**STREET ADDRESS:**

Lazarus Government Center  
50 W. Town St., Suite 700  
Columbus, Ohio 43215

**Central District Office**

TELE: (614) 728-3778 FAX: (614) 728-3898  
www.epa.state.oh.us

**MAILING ADDRESS:**

P.O. Box 1049  
Columbus, OH 43216-1049

July 29, 2010

Mike Bashore  
Franklin County Engineer  
970 Dublin Road  
Columbus, OH 43215

**Re: Construction Storm Water Inspection at Main Street in Westerville Bridge Replacement Over Alum Creek/Franklin County.  
Permit Number: 4GC03229\*AG**

Dear Mr. Bashore:

This letter is written regarding the storm water inspection conducted by Vinod Tujalpuram of Ohio EPA, at the Main Street Bridge Replacement over Alum Creek located in Westerville Ohio on July 23, 2010. The Agency understands that these construction activities are currently covered under the General Storm Water Permit Associated with Construction Activities. Based on the site inspection and the General Storm Water Permit, the following items were noted:

**Sediment and Erosion Controls:**

- It appears majority of the sediment and erosion controls are in place and functioning as intended.
- Silt fence should be installed along the Northwest end of the project to minimize sediment run off into Alum Creek (Figure 1).
- The inlet protection located northeast of the project requires maintenance at this time. Please ensure all inlet protections are covered appropriately to meet the requirements of your General Storm Water Permit.

**Maintenance**

- The sediment controls implemented on this site will require maintenance or reinstallation to ensure a proper functioning condition. This general permit states that all sediment controls will be inspected and maintained every seven days or within 24 hours of a precipitation event equal to or greater than 0.5 inches. A log of inspection must be maintained on site for the agency to review.


Ted Strickland, Governor  
Lee Fisher, Lieutenant Governor  
Chris Korleski, Director

Ohio EPA is an Equal Opportunity Employer

Mike Bashore  
Franklin County Engineer  
Page -2-

If you have any questions regarding this letter or the inspection, please do not hesitate to call me at our Central District Office at (614) 728-3844 or email at [harry.kallipolitis@epa.state.oh.us](mailto:harry.kallipolitis@epa.state.oh.us). A follow-up inspection will be conducted to ensure the conditions of the General Permit are met.

Sincerely,



Harry Kallipolitis  
Storm Water Coordinator  
Division of Surface Water  
Central District Office

c: Jeff Bohne, Water Quality Supervisor, DSW/CDO

HK/nsm Main Street Bridge Replacement over Alum Creek 7-23-10