



State of Ohio Environmental Protection Agency

STREET ADDRESS:

Central District Office

MAILING ADDRESS:

Lazarus Government Center
50 W. Town St., Suite 700
Columbus, Ohio 43215

TELE: (614) 728-3778 FAX: (614) 728-3898
www.epa.state.oh.us

P.O. Box 1049
Columbus, OH 43216-1049

July 29, 2010

Lloyd Helber
Pizza Cottage
PO Box 2550
Lancaster, OH 43130

**Re: Storm Water Inspection at Pizza Cottage - Pickerington / Fairfield County
Permit No: 4GC03093*AG**

Dear Mr. Helber:

This letter is written in follow up to a construction storm water inspection by Elizabeth Schaller and Stephen Riley of the Ohio EPA conducted at Pizza Cottage located at 1000 Old Diley Road in Pickerington, Ohio on July 27, 2010. The purpose of the inspection was to evaluate compliance with the General Storm Water Permit Associated with Construction Activities. During the inspection, the following items were noted:

It appeared during the inspection that construction activity is completed for this site and all disturbed areas had been permanently stabilized. A Notice of Termination will be required provided the following requirements are met.

- Please remove street storm drain inlet covers as they are no longer necessary.
- Vegetation must be established sufficient to control erosion which is measured by a minimum vegetative density of 70%.
- The General Storm Water Permit requires specific post construction water quality treatment for all sites. Guidance regarding the post construction mandates can be found at:
<http://www.epa.state.oh.us/dsw/storm/CGPPCQA.aspx>. Please submit to my attention (email preferred at harry.kallipolitis@epa.state.oh.us) which practice will be installed at this site to ensure compliance with the General Permit. Please include all design criteria with your submittal.
- A Notice of Termination (NOT) must be submitted once the post construction requirements are verified. The NOT form and filing instructions can be found at:
<http://www.epa.state.oh.us/dsw/storm/stormform.aspx>.

Ted Strickland, Governor
Lee Fisher, Lieutenant Governor
Chris Korleski, Director

Lloyd Helber
Pizza Cottage
Page -2-

If you have any questions regarding this letter or the inspection, please do not hesitate to contact me at our Central District Office at (614) 728-3844.

Sincerely,



Harry Kallipolitis
Storm Water Coordinator
Division of Surface Water
Central District Office

c: Jeff Bohne, Water Quality Supervisor, DSW/CDO

HK/nsm Pizza Cottage Pickerington 7-27-10



State of Ohio Environmental Protection Agency

STREET ADDRESS:

Lazarus Government Center
50 W. Town St., Suite 700
Columbus, Ohio 43215

Central District Office

TELE: (614) 728-3778 FAX: (614) 728-3898
www.epa.state.oh.us

MAILING ADDRESS:

P.O. Box 1049
Columbus, OH 43216-1049

June 29, 2010

Brad Jones
ODOT District 6
400 E. William Street
Delaware, OH 43015

**Re: Construction Storm Water Inspection at ODOT District 6, Site: MAD-40-1496
Permit Number 4GD00061*AG**

Dear Mr. Jones,

This letter is written in follow-up to a construction storm water inspection I conducted at MAD-40-1496 in West Jefferson, Ohio on June 12, 2010. The purpose of the inspection was to evaluate compliance with the General Storm Water Permit Associated with Construction Activities. During the inspection, I noted the following issues associated with construction activities at this site:

Sediment and Erosion Control:

- During the inspection, I noticed the majority of the site was draining to a centralized sediment basin appropriate for the construction of this site.

Inlet Protection

- The inlet protections failed to meet the minimum criteria of the ODOT Land and Development Manual. Please implement corrective measures.

If you have any questions regarding this letter or the inspection, please do not hesitate to contact me at our Central District Office at (614) 728-3844. A follow-up inspection will be conducted to ensure the conditions of the General Permit are met.

Sincerely,

Harry Kallipolitis
Storm Water Coordinator
Division of Surface Water
Central District Office

c: Jeff Bohne, Water Quality Supervisor, DSW/CDO

HK/nsm ODOT District 6, MAD-401496 7-12-10

Ted Strickland, Governor
Lee Fisher, Lieutenant Governor
Chris Korleski, Director