



State of Ohio Environmental Protection Agency

STREET ADDRESS:

Lazarus Government Center
50 W. Town St., Suite 700
Columbus, Ohio 43215

Central District Office

TELE: (614) 728-3778 FAX: (614) 728-3898
www.epa.state.oh.us

MAILING ADDRESS:

P.O. Box 1049
Columbus, OH 43216-1049

July 28, 2010

Warren Hubbard
Columbus Public Schools
889 East 17th Street
Columbus OH 43211

**Re: Construction Storm Water Inspection at Harley Field / Franklin County.
Permit Number: 4GC02962*AG**

Dear Mr. Hubbard:

This letter is written regarding the storm water inspection conducted by Vinod Tujalpuram and Michael Shields of Ohio EPA, at Harley Field located 1810 Greenway Avenue, Columbus on July 16, 2010. The Agency understands that these construction activities are currently covered under the General Storm Water Permit Associated with Construction Activities. Based on the site inspection and the General Storm Water Permit, the following items were noted;

Sediment and Erosion Controls:

- It appears the sediment and erosion controls are in place and functioning as intended. Please continue to maintain all sediment controls associated with the site via your required self inspection every seven days or within 7 day of a rain event equal to or greater than 0.5 inches.

If you have any questions regarding this letter or the inspection, please do not hesitate to call me at our Central District Office at (614) 728-3844 or email at harry.kallipolitis@epa.state.oh.us. A follow up inspection will be conducted to ensure the conditions of the General Permit are met.

Sincerely,

Harry Kallipolitis
Storm Water Coordinator
Division of Surface Water
Central District Office

c: Jeff Bohne, Water Quality Supervisor

HK/nsm Harley Field 7-16-2010

Ted Strickland, Governor
Lee Fisher, Lieutenant Governor
Chris Korleski, Director



