



State of Ohio Environmental Protection Agency

STREET ADDRESS:

Parus Government Center
50 W. Town St., Suite 700
Columbus, Ohio 43215

Central District Office

TELE: (614) 728-3778 FAX: (614) 728-3898
www.epa.state.oh.us

MAILING ADDRESS:

P.O. Box 1049
Columbus, OH 43216-1049

June 28, 2010

Dave Carmendy
DLC Electric
233 South Liberty Street
Powell, OH 43065

**Re: Construction Storm Water Inspection at Carmendy Station / Delaware County
Permit Number 4GC02974*AG**

Dear Mr. Carmendy:

This letter is written in follow-up to a construction storm water inspection conducted by Elizabeth Schaller and Abigail Tamkin of Ohio EPA at Carmendy Station in Powell, Ohio on June 22, 2010. The purpose of the inspection was to evaluate compliance with the General Storm Water Permit Associated with Construction Activities. During the inspection, our inspection staff noted the following issues associated with construction activities at this site:

Sediment and Erosion Control:

- The silt fence around perimeter must be monitored and maintained as portions have failed and no longer function as intended. The silt fence must be trenched in, otherwise proper reinstallation will be required (see figure 1).
- Inlet protections (Dandy Bags or equivalent) must be replaced as they have holes and no longer function as intended (see figure 2). In addition, please check the installation of laterally supported inlet protections.

If you have any question regarding this letter or the inspection, please do not hesitate to contact me at our Central District Office at (614) 728-3844. A follow-up inspection will be conducted to ensure the conditions of the General Permit are met.

Sincerely,

Harry Kallipolitis
Storm Water Coordinator
Division of Surface Water
Central District Office

c: Jeff Bohne, Water Quality Supervisor CDO/DSW

HK/nsm Carmendy Station 7-22-2010

Ted Strickland, Governor
Lee Fisher, Lieutenant Governor
Chris Korleski, Director

