





Environmental
Protection Agency

John R. Kasich, Governor
Mary Taylor, Lt. Governor
Scott J. Nally, Director

Re: Sandusky County
Ballville Subway
TNC Water System
PWS ID # OH 7258612

August 3, 2011

Ms. Holly Loper
Ballville Subway
1000 North Front Street
Fremont, Ohio 43420

Dear Ms. Loper:

This letter will confirm removal of the water use advisory required in our letter dated July 27, 2011. This is based on one set of four total coliform negative (safe) samples collected on July 18, 2011, and were received by the Ohio EPA on August 1, 2011. They were initially reported by the laboratory with the wrong collection date on the sample results.

This office has not received a copy of the public notice, which was issued. Send a copy of the public notice along with the verification form to the Ohio EPA, 347 North Dunbridge Road, Bowling Green, OH 43402 by August 16, 2011.

When a public water system monitoring with fewer than five routine samples per month has one or more total coliform-positive samples, the public water system shall monitor with at least five samples during the next month that the system provides water to the public. It is the responsibility of the water system to collect five samples during the month of August 2011.

Yours truly,



Kimberly K. Burnham, R.S.
Division of Drinking and Ground Waters

/llr

pc: Sandusky County Health Department
IMS, DDAGW, CO, Attn: Toni Buchanan
DDAGW, NWDO

