



State of Ohio Environmental Protection Agency

Southeast District Office

2195 Front Street
Logan, Ohio 43138

TELE (740) 385-8501 FAX (740) 385-6490
www.epa.state.oh.us

Ted Strickland, Governor
Lee Fisher, Lieutenant Governor
Chris Korleski, Director

October 21, 2008

Re: Monroe County
G & N Sportsbar and Grill
Reconnaissance Inspection
NPDES Permit OPR00153*AD
Correspondence (PWW)

Mr. Neal Wittenbrook
49404 State Route 800
Jerusalem, Ohio 43747

Dear Mr. Wittenbrook:

On October 4, 2008, I conducted an inspection of G & N Sportsbar and Grill. Gina was present for the inspection of the facility. The purpose of the inspection was to determine how the plant was operating and to obtain the correct address for your facility. Results of the inspection are summarized below.

At the time of the inspection, the plant did not appear to be operating properly. The plant had a strong odor and a strong odor should not be present if it is functioning properly. This may be due to a few factors. First, the aeration system was not on at the time of the inspection. You have a fixed-activated sludge treatment (FAST) unit and the aeration system should be on continuously. If you are having trouble with the aeration system you should contact the installer to assist you. Second, experiment with the cleaning products you are using in your facility. Your treatment plant relies on microbial growth to treat the wastewater. Sometimes the cleaning products can kill the microbes; this makes the wastewater hard to treat. Please let me know if you continue to experience additional odors from your wastewater treatment plant. Please note you must chlorinate your effluent between the dates May 1st and October 31st.

At the time of the inspection, I gave Gina the copy of the NPDES permit; please read through the permit and follow the sampling schedule. You should be receiving your official permit package in the mail shortly.

If you have any questions, please call me at (740) 380-5266, or Scott Foster at (740) 380-5227.

Sincerely,

Cynthia Yandrich
District Representative
Division of Surface Water

CY/dh

Enclosure

NPDES Compliance Inspection Report

A. NATIONAL DATA SYSTEM CODING

Permit No.	NPDES No.	Date	Inspection Type	Inspector	Facility Type
OPR00153*AD	OH0135275	October 4, 2008	R	S	1

B. FACILITY DATA

Name and Location of Facility Inspected	Entry Time	Permit Effective Date
G & N Sportsbar and Grill Corner of State Route 800 and State Route 145 Malaga, Ohio, Monroe County	3:15 p.m.	September 1, 2008
	Exit Time	Permit Expiration Date
	3:30 p.m.	August 31, 2013

Name(s) and Title(s) of On-Site Representative(s)	Phone Number(s)
Gina, Manager	(740) 472-0914
Name, Address and Title of Responsible Official	Phone Number
Neal Wittenbrook, Owner 49404 State Route 800 Jerusalem, Ohio 43747	(740) 472-0914

C. AREAS EVALUATED DURING INSPECTION

<u> </u> N Permit	<u> </u> N Flow Measurement	<u> </u> N Pretreatment
<u> </u> N Records/Reports	<u> </u> N Laboratory	<u> </u> N Compliance Schedules
<u> </u> M Operations & Maintenance	<u> </u> N Effluent/Receiving Waters	<u> </u> N Self-Monitoring Program
<u> </u> S Facility Site Review	<u> </u> N Sludge Storage/Disposal	<u> </u> Other
<u> </u> N Collection System		


(S = Satisfactory, M = Marginal, U = Unsatisfactory, N = Not Evaluated)

D. SUMMARY OF FINDINGS/COMMENTS (attach additional sheets if necessary)

See attached letter.


 Cynthia Yandrich, Inspector, Ohio EPA, Southeast District Office

10 - 21 - 08
 Date


 Timothy M. Campbell, Reviewer, Ohio EPA, Southeast District Office

10/22/08
 Date