



State of Ohio Environmental Protection Agency

STREET ADDRESS:

Central District Office

MAILING ADDRESS:

Garzarus Government Center
50 W. Town St., Suite 700
Columbus, Ohio 43215

TELE: (614) 728-3778 FAX: (614) 728-3898
www.epa.state.oh.us

P.O. Box 1049
Columbus, OH 43216-1049

July 26, 2010

Roger Loomis
City of Newark
34 South 5th Street
Newark, OH 43055

**Re: Construction Storm Water Inspection at Newark WWTP / Licking County
Permit Number: 4GC03069*AG**

Dear Mr. Loomis:

This letter is written regarding a storm water inspection conducted by Abigail Tamkin and Michael Shields of the Ohio EPA at the Newark WWTP located at 1003 East Main Street on July 19, 2010. The purpose of the inspection was to evaluate compliance with the General Storm Water Permit Associated with Construction Activities. During the inspection, our staff noted the following issues associated with construction activities at this site:

Sediment and Erosion Control:

- Please examine the perimeter silt fence. There were several places that appeared to be in poor condition which require repair.
- Be aware the General Permit states that all barren areas which remain idle in excess of 21 days must be protected from erosion within seven days of the last earth disturbing activities. In addition, erosion protection must be implemented for all areas of final grade within seven (7) days.

If you have any questions regarding this letter or the inspection, please do not hesitate to contact me at our Central District Office at 614-728-3844 or email at harry.kallipolitis@epa.state.oh.us.

Sincerely,

Harry Kallipolitis
Storm Water Coordinator
Division of Surface Water
Central District Office

c: Jeff Bohne, Water Quality Supervisor, DSW/CDO

HK/nsm Newark WWTP 7-19-2010

Ted Strickland, Governor
Lee Fisher, Lieutenant Governor
Chris Korleski, Director



