



State of Ohio Environmental Protection Agency

STREET ADDRESS:

W. Zarus Government Center
50 W. Town St., Suite 700
Columbus, Ohio 43215

Central District Office

TELE: (614) 728-3778 FAX: (614) 728-3898
www.epa.state.oh.us

MAILING ADDRESS:

P.O. Box 1049
Columbus, OH 43216-1049

July 26, 2010

David Sennett
US Army COE
PO Box 3990
Whitehall, OH 43218

**Re: Construction Storm Water Inspection at Whitehall Defense Supply Center-
DSCC/Franklin County.
Permit Number: 4GC02866*AG**

Dear Mr. Sennett:

This letter is written regarding the storm water inspection conducted by Vinod Tujalpuram and Michael Shields of Ohio EPA, at Whitehall Defense Supply Center located 508 North James Road, Whitehall, Ohio on July 16, 2010. The Agency understands that these construction activities are currently covered under the General Storm Water Permit Associated with Construction Activities. Based on the site inspection and the General Storm Water Permit, the following items were noted;

Sediment and Erosion Controls:

- All disturbed areas must be protected with silt fence or an appropriate alternative to address sediment and erosion controls (Figure 1).
- Please ensure all inlet protections are covered appropriately to meet the requirements of your General Storm Water Permit (Figure 2).

Maintenance:

- The sediment controls implemented on this site will require maintenance or reinstallation to ensure a proper functioning condition. This general permit states that all sediment controls will be inspected and maintained every seven days or within 24 hours of a precipitation event equal to or greater than 0.5 inches. A log of inspection must be maintained on site for the agency to review.

Post Construction:

- The General Storm Water Permit requires specific post construction water quality treatment for all sites. Guidance regarding the post construction requirements is found at: <http://www.epa.state.oh.us/dsw/storm/CGPPCQA.aspx>. Please submit to my attention (email preferred at harry.kallipolitis@epa.state.oh.us) which practice will be installed at this site to ensure compliance with the General Permit. Please include all design criteria and calculations in your submission.

Ted Strickland, Governor
Lee Fisher, Lieutenant Governor
Chris Korteski, Director

David Sennett
US Army COE
Page -2-

If you have any questions regarding this letter or the inspection, please do not hesitate to call me at our Central District Office at (614) 728-3844 or email at harry.kallipolitis@epa.state.oh.us. A follow-up inspection will be conducted to ensure the conditions of the General Permit are met.

Sincerely,



Harry Kallipolitis
Storm Water Coordinator
Division of Surface Water
Central District Office

c: Jeff Bohne, Water Quality Supervisor, DSW/CDO

HK/nsm Whitehall Defense Supply Center, 7-16-10



Figure 1: Silt fence will require maintenance




Figure 2: All inlet Protections are to be covered.

