



State of Ohio Environmental Protection Agency

STREET ADDRESS:

Lazarus Government Center
50 W. Town St., Suite 700
Columbus, Ohio 43215

Central District Office

TELE: (614) 728-3778 FAX: (614) 728-3898
www.epa.state.oh.us

MAILING ADDRESS:

P.O. Box 1049
Columbus, OH 43216-1049

July 26, 2010

John Trujillo
City of Newark
40 West Main Street
Newark, OH 43055

**Re: Construction Storm Water Inspection at Garfield McKinley Storm Sewer Project Phase II
Licking County
Permit Number: 4GC03263*AG**

Dear Mr. Trujillo:

This letter is written regarding a storm water inspection conducted by Abigail Tamkin and Michael Shields of the Ohio EPA at the Garfield McKinley Storm Sewer Project Phase II located at OBannon and Garfield Avenues on July 19, 2010. The purpose of the inspection was to evaluate compliance with the General Storm Water Permit Associated with Construction Activities. During the inspection, our staff noted the following issues associated with construction activities at this site:

Sediment and Erosion Control:

- There was no apparent perimeter sediment control associated with this site. Please install silt fence or a provable alternative to minimize the amount of sediment leaving the site.
- Inlet protections were observed and appeared to be in good repair.

If you have any questions regarding this letter or the inspection, please do not hesitate to contact me at our Central District Office at 614-728-3844 or email at harry.kallipolitis@epa.state.oh.us.

Sincerely,

Harry Kallipolitis
Storm Water Coordinator
Division of Surface Water
Central District Office

c: Jeff Bohne, Water Quality Supervisor, DSW/CDO

HK/nsm Garfield McKinley Storm Sewer Project Phase II 7-19-2010

Ted Strickland, Governor
Lee Fisher, Lieutenant Governor
Chris Korieski, Director



