



State of Ohio Environmental Protection Agency

STREET ADDRESS:

Zarus Government Center
50 W. Town St., Suite 700
Columbus, Ohio 43215

Central District Office

TELE: (614) 728-3778 FAX: (614) 728-3898
www.epa.state.oh.us

MAILING ADDRESS:

P.O. Box 1049
Columbus, OH 43216-1049

July 23, 2010

Kenneth Stewart
Jobs Henderson & Associates Inc.
59 Grant Street
Newark, OH 43055

**Re: Construction Storm Water Inspection at OSU Lincoln & Morill Tower
Franklin County.
Permit Number: 4GC03236*AG**

Dear Mr. Stewart:

This letter is written regarding the storm water inspection conducted by Vinod Tujalpuram of Ohio EPA at **OSU Lincoln & Morill Tower** located 1800 Cannon Drive, Columbus, Ohio on July 14, 2010. The Agency understands that these construction activities are currently covered under the General Storm Water Permit Associated with Construction Activities. Based on the site inspection and the General Storm Water Permit, the following items were noted;

Sediment and Erosion Controls:

- All disturbed areas must be protected with silt fence or designated alternative to address sediment and erosion controls.
- The silt fence located south of Morill tower requires maintenance at this time.
- The inlet protections are clogged due to the recent rain event. Please ensure all inlet protections are covered appropriately to meet the requirements of your General Storm Water Permit.
- Please ensure all dewatering from the impoundments do not result in turbid discharges to the surface waters of the state.

If you have any questions regarding this letter or the inspection, please do not hesitate to call me at our Central District Office at (614) 728-3844 or email at harry.kallipolitis@epa.state.oh.us. A follow-up inspection will be conducted to ensure the conditions of the General Permit are met.

Sincerely,

Harry Kallipolitis
Storm Water Coordinator
Division of Surface Water
Central District Office

c: Jeff Bohne, Water Quality Supervisor, DSW/CDO

HK/nsm OSU Lincoln & Morill Tower, 7-14-2010

Ted Strickland, Governor
Lee Fisher, Lieutenant Governor
Chris Korleski, Director



