



State of Ohio Environmental Protection Agency

STREET ADDRESS:

Starus Government Center
50 W. Town St., Suite 700
Columbus, Ohio 43215

Central District Office

TELE: (614) 728-3778 FAX: (614) 728-3898
www.epa.state.oh.us

MAILING ADDRESS:

P.O. Box 1049
Columbus, OH 43216-1049

July 23, 2010

Cindy Phillips
Eastside Grace Brethren Church/Christian School
7510 E Broad St
Blacklick, OH 43004

**Re: Storm Water Inspection at Eastside Grace Brethren Church/Christian School
Franklin County
Permit No: 4GC02934*AG**

Dear Ms. Phillips:

This letter is written in follow-up to a construction storm water inspection by Stephen Riley & Abigail Tamkin, of the Ohio EPA, conducted at Eastside Grace Brethren Church/Christian School located at the intersection of 7510 E Broad St, on July 14, 2010. The purpose of the inspection was to evaluate compliance with the General Storm Water Permit Associated with Construction Activities. During the inspection, the following items were noted:

It appeared during the inspection that construction activity is completed for this site and all disturbed areas had been permanently stabilized. A Notice of Termination will be required provided the following requirements are met.

- Vegetation must be established sufficient to control erosion which is measured by a minimum vegetative density of 70%.
- The General Storm Water Permit requires specific post construction water quality treatment for all sites. Guidance regarding the post construction mandates can be found at:
<http://www.epa.state.oh.us/dsw/storm/CGPPCQA.aspx>. Please submit to my attention (email preferred at harry.kallipolitis@epa.state.oh.us) which practice will be installed at this site to ensure compliance with the General Permit. Please include all design criteria with your submittal.
- A Notice of Termination (NOT) must be submitted once the post construction requirements are verified. The NOT form and filing instructions can be found at:
<http://www.epa.state.oh.us/dsw/storm/stormform.aspx>.

Ted Strickland, Governor
Lee Fisher, Lieutenant Governor
Chris Korteski, Director

Ohio EPA is an Equal Opportunity Employer



Cindy Phillips
Eastside Grace Brethren Church/Christian School
Page -2-

If you have any questions regarding this letter or the inspection, please do not hesitate to contact me at our Central District Office at (614) 728-3844.

Sincerely,



Harry Kallipolitis
Storm Water Coordinator
Division of Surface Water
Central District Office

c: Jeff Bohne, Water Quality Supervisor, DSW/CDO

HK/nsm East Side Grace Brethren Church, Christian School 7-14-2010