



State of Ohio Environmental Protection Agency

STREET ADDRESS:

Cazarus Government Center
50 W. Town St., Suite 700
Columbus, Ohio 43215

Central District Office

TELE: (614) 728-3778 FAX: (614) 728-3898
www.epa.state.oh.us

MAILING ADDRESS:

P.O. Box 1049
Columbus, OH 43216-1049

July 23, 2010

Don McCarthy
Scitech
c/o McCarthy Consulting LLC.
84 West Riverglen Drive
Worthington, OH 43085

**Re: Construction Storm Water Inspection at Scitech Wireless Communication Building/ Franklin County.
Permit Number: 4GC03218*AG**

Dear Mr. McCarthy:

This letter is written regarding the storm water inspection conducted by Vinod Tujalpuram at **Scitech Wireless Communication Building** located 1330 Kinnear Road on July 14, 2010. The Agency understands that these construction activities are currently covered under the General Storm Water Permit Associated with Construction Activities. Based on the site inspection and the General Storm Water Permit, the following items were noted;

Sediment Erosion Controls:

- The inlet protections are clogged due to the recent storm event, and must be maintained.
- Please ensure all inlet protections are covered appropriately to minimize the sediment and erosion controls, and to ensure compliance with requirements of the General Storm Water Permit.

Maintenance Requirements:


- The General Permit requires the permittee to conduct inspections of all sediment and erosion controls every seven days or within 24 hours of a rain event equal to or greater than 0.5 inches. A log of the inspections and resulting corrective actions must be maintained on site available for review. All earth disturbing activities must be clearly documented in your inspection reports to ensure the temporary or permanent stabilization requirements are not violated.

Ted Strickland, Governor
Lee Fisher, Lieutenant Governor
Chris Korteski, Director

Don McCarthy
Scitech
Page -2-

If you have any question regarding this letter or the inspection, please do not hesitate to contact me at our Central District Office at (614) 728-3844 or email at harry.kallipolitis@epa.state.oh.us. A follow up inspection will be conducted to ensure the conditions of the General Permit are met.

Sincerely,



Harry Kallipolitis
Storm Water Coordinator
Ohio EPA, Division of Surface Water
Central District Office

HK/nsm Scitech Wireless Bldg 7-14-2010