



State of Ohio Environmental Protection Agency

STREET ADDRESS:

Cazarus Government Center  
50 W. Town St., Suite 700  
Columbus, Ohio 43215

Central District Office

TELE: (614) 728-3778 FAX: (614) 728-3898  
www.epa.state.oh.us

MAILING ADDRESS:

P.O. Box 1049  
Columbus, OH 43216-1049

July 23, 2010

Gary Collier  
The Ohio State University  
2003 Millikin Road  
Columbus, OH 43210

**Re: Construction Storm Water Inspection at Woody Hayes Athletic Center-  
Football Field/ Franklin County.  
Permit Number: 4GC03248\*AG**

Dear Mr. Collier:

This letter is written regarding the storm water inspection conducted by Vinod Tujalpuram at **Woody Hayes Athletic Center- Football Field** located 2491 Olentangy River Road, Columbus on July 14, 2010. The Agency understands that these construction activities are currently covered under the General Storm Water Permit Associated with Construction Activities. Based on the site inspection and the General Storm Water Permit, the following items were noted:

**Sediment Erosion Controls:**

- Silt fence on the northeast portion of the project will require maintenance at this time. Corrective measures must be implemented within three days from receipt of this letter.
- Please ensure all inlet protections are covered appropriately to minimize the sediment and erosion controls, and to ensure compliance with requirements of the General Storm Water Permit.

**Maintenance Requirements:**

- The General Permit requires the permittee to conduct inspections of all sediment and erosion controls every seven days or within 24 hours of a rain event equal to or greater than 0.5 inches. A log of the inspections and resulting corrective actions must be maintained on site available for review. All earth disturbing activities must be clearly documented in your inspection reports to ensure the temporary or permanent stabilization requirements are not violated.

Ted Strickland, Governor  
Lee Fisher, Lieutenant Governor  
Chris Korteski, Director

Gary Collier  
The Ohio State University  
Page -2-

If you have any question regarding this letter or the inspection, please do not hesitate to contact me at our Central District Office at (614) 728-3844 or email at [harry.kallipolitis@epa.state.oh.us](mailto:harry.kallipolitis@epa.state.oh.us). A follow- up inspection will be conducted to ensure the conditions of the General Permit are met.

Sincerely,



Harry Kallipolitis  
Storm Water Coordinator  
Division of Surface Water  
Central District Office