



State of Ohio Environmental Protection Agency

**STREET ADDRESS:**

Blazarus Government Center  
50 W. Town St., Suite 700  
Columbus, Ohio 43215

**Central District Office**

TELE: (614) 728-3778 FAX: (614) 728-3898  
www.epa.state.oh.us

**MAILING ADDRESS:**

P.O. Box 1049  
Columbus, OH 43216-1049

July 23, 2010

Tom Carmody  
OSU- Facilities, Operation & Development  
400 Central Classroom,  
2009 Millikin Road  
Columbus, OH 43015

**Re: Construction Storm Water Inspection at West Campus Substation  
Franklin County.  
Permit Number: 4GC03293\*AG**

Dear Mr. Carmody:

This letter is written regarding the storm water inspection conducted by Vinod Tujalpuram at **West Campus Substation** located 1991 Kenny Road on July 14, 2010. The Agency understands that these construction activities are currently covered under the General Storm Water Permit Associated with Construction Activities. Based on the site inspection and the General Storm Water Permit, the following items were noted;

**Sediment Erosion Controls:**

- The silt fence on the southern portion of the site has failed and will require maintenance at this time.
- Stock piles located on site must be seeded and mulched to minimize sediment runoff to the surface waters of the state.
- Please ensure the dewatering activities noted on site will not result in turbid discharges to waters of the state.

**Maintenance Requirements:**


- The General Permit requires the permittee to conduct inspections of all sediment and erosion controls every seven days or within 24 hours of a rain event equal to or greater than 0.5 inches. A log of the inspections and resulting corrective actions must be maintained on site available for review. All earth disturbing activities must be clearly documented in your inspection reports to ensure the temporary or permanent stabilization requirements are not violated.

Ted Strickland, Governor  
Lee Fisher, Lieutenant Governor  
Chris Korleski, Director

Tom Carmody  
OSU- Facilities, Operation & Development  
Page -2-

If you have any question regarding this letter or the inspection, please do not hesitate to contact me at our Central District Office at (614) 728-3844 or email at [harry.kallipolitis@epa.state.oh.us](mailto:harry.kallipolitis@epa.state.oh.us). A follow-up inspection will be conducted to ensure the conditions of the General Permit are met.

Sincerely,



Harry Kallipolitis  
Storm Water Coordinator  
Division of Surface Water  
Central District Office

c: Jeff Bohne, Water Quality Supervisor, DSW/CDO

HK/nsm OSU West Campus Substation 7-14-2010