



State of Ohio Environmental Protection Agency

STREET ADDRESS:

Warren Government Center
50 W. Town St., Suite 700
Columbus, Ohio 43215

Central District Office

TELE: (614) 728-3778 FAX: (614) 728-3898
www.epa.state.oh.us

MAILING ADDRESS:

P.O. Box 1049
Columbus, OH 43216-1049

July 22, 2010

Matt Lambert
Delaware County Regional Sewer District
50 Channing Street
Delaware, Ohio 43015

**Re: Construction Storm Water Inspection at Cheshire Elementary School Sanitary
Sewer Improvement
Permit Number: 4GC03211*AG**

Dear Mr. Lambert:

This letter is written regarding the storm water inspection; I conducted at **Cheshire Elementary School Sanitary Sewer Improvement** located Cheshire Road between Gregory Road & Lackey Old State Road Delaware Ohio on July 7, 2010. The Agency understands that these construction activities are currently covered under the General Storm Water Permit Associated with Construction Activities. Based on the site inspection and the General Storm Water Permit, the following items were noted:

Post Construction:

- The General Storm Water Permit requires specific post construction water quality treatment for all sites. Guidance regarding the post construction requirements is found at:
<http://www.epa.state.oh.us/dsw/storm/CGPPCQA.aspx>. Please submit to my attention (email preferred at harry.kallipolitis@epa.state.oh.us) which practice will be installed at this site to ensure compliance with the General Permit. Please include all design criteria and calculations in your submission.

Sanitary Sewer Line Evaluation:

- I inspected the sanitary sewer line installation and the associated storm water controls. The perimeter controls in several areas have fallen and will require maintenance.
- It appears that the initial installation of the sediment controls has been installed without appropriate maintenance activities. At this time, I am formally requesting your copy of inspection logs as required by the General Storm Water Permit.

Ted Strickland, Governor
Lee Fisher, Lieutenant Governor
Chris Korleski, Director

Matt Lambert
Delaware County Regional Sewer District
Page -2- *

If you have any questions regarding this letter or the inspection, please do not hesitate to call me at our Central District Office at (614) 728-3844 or email at harry.kallipolitis@epa.state.oh.us. In addition, please provide a written response to the action items addressed above within ten days from receipt of this letter. A follow-up inspection will be conducted to ensure the minimum conditions of the General Permit have been met.

Sincerely,



Harry Kallipolitis
Storm Water Coordinator
Division of Surface Water
Central District Office

c: Jeff Bohne, Water Quality Supervisor, DSW/CDO

HK/nsm Cheshire School Sanitary Sewer 7-7-2010