



State of Ohio Environmental Protection Agency

REET ADDRESS:

**Central District Office**

MAILING ADDRESS:

Edzarus Government Center  
50 W. Town St., Suite 700  
Columbus, Ohio 43215

TELE: (614) 728-3778 FAX: (614) 728-3898  
www.epa.state.oh.us

P.O. Box 1049  
Columbus, OH 43216-1049

July 22, 2010

Mike Bashore  
Franklin County Engineer's Office  
970 Dublin Road  
Columbus, OH 43215

**Re: Construction Storm Water Inspection at Morse Road at Reynoldsburg-New  
Albany Road Roundabout  
Permit Number: 4GC03221\*AG**

Dear Mr. Bashore:

This letter is written regarding the storm water inspections I conducted at Morse Road at Reynoldsburg-New Albany Road Roundabout located Morse Road & Reynoldsburg-New Albany Road in Blacklick, Ohio on June 30 and July 7, 2010. The Agency understands that these construction activities are currently covered under the General Storm Water Permit Associated with Construction Activities. Based on the site inspection and the General Storm Water Permit, the following items were noted:

**Sediment Erosion Controls:**

- During the investigation, I evaluated the sediment controls associated with the site. Two storm water basins have been installed. It is my understanding; these basins are alternatives to the construction storm water permit.
- Please ensure all dewatering from the impoundments do not result in turbid discharges to the surface waters of the state.
- I noted that the weekly stabilization measures are currently underway.
- Please advise me regarding your resolution associated with Mr. Sell's property.
- It is my understanding there are resolutions currently being evaluated to address this drainage concerns.

Ted Strickland, Governor  
Lee Fisher, Lieutenant Governor  
Chris Korleski, Director



Mike Bashore  
Franklin County Engineer's Office  
Page -2-

If you have any questions regarding this letter or the inspection, please do not hesitate to call me at our Central District Office at (614) 728-3844 or email at [harry.kallipolitis@epa.state.oh.us](mailto:harry.kallipolitis@epa.state.oh.us). In addition, please provide a written response to the action items addressed above within ten days from receipt of this letter. A follow-up inspection will be conducted to ensure the minimum conditions of the General Permit have been met.

Sincerely,



Harry Kallipolitis  
Storm Water Coordinator  
Division of Surface Water  
Central District Office

c: Jeff Bohne, Water Quality Supervisor, CDO/DSW

HK/nsm Morse Road – New Albany Rd. Roundabout 7-7-2010