



State of Ohio Environmental Protection Agency

STREET ADDRESS:

Ezraus Government Center  
50 W. Town St., Suite 700  
Columbus, Ohio 43215

**Central District Office**

TELE: (614) 728-3778 FAX: (614) 728-3898  
www.epa.state.oh.us

MAILING ADDRESS:

P.O. Box 1049  
Columbus, OH 43216-1049

July 22, 2010

Brad Jones  
ODOT District 6  
400 E. William Street  
Delaware, OH 43015

**Re: Construction Storm Water Inspection at MAD-40-1496 / Madison County  
Permit No: 4GCD00061\*AG**

Dear Mr. Jones:

This letter is written regarding the storm water inspections, I conducted at **MAD- 40-1496** on July 12, 2010. The Agency understands these construction activities are currently covered under the General Storm Water Permit Associated with Construction Activities. Based on the site inspection and the General Storm Water Permit, the following items must be addressed:

**Sediment Erosion Controls:**

- During the inspection I noted the centralized basin adjacent to the Big Darby Creek. The centralized sediment basin is currently receiving drainage from the entire site. The discharges appear relatively clear which are directed into the main stem of Big Darby Creek.
- Inlet protections noted on the site are inadequate. Corrective measures must be implemented to ensure that the inlet protections are designed in accordance to the ODOT Standards.

If you have any questions regarding this letter or the inspection, please do not hesitate to call me at our Central District Office at (614) 728-3844 or email at:

[harry.kallipolitis@epa.state.oh.us](mailto:harry.kallipolitis@epa.state.oh.us). In addition, please provide a written response to the action items addressed above within ten days from receipt of this letter. A follow-up inspection will be conducted to ensure the minimum conditions of the General Permit have been met.

Sincerely,

Harry Kallipolitis  
Storm Water Coordinator  
Division of Surface Water  
Central District Office

c: Jeff Bohne, Water Quality Supervisor

HK/nsm MD-4- ODOT 6 7-12-2010

Ted Strickland, Governor  
Lee Fisher, Lieutenant Governor  
Chris Kortesi, Director

