



State of Ohio Environmental Protection Agency

STREET ADDRESS:

**Central District Office**

MAILING ADDRESS:

Lezarus Government Center  
50 W. Town St., Suite 700  
Columbus, Ohio 43215

TELE: (614) 728-3778 FAX: (614) 728-3898  
[www.epa.state.oh.us](http://www.epa.state.oh.us)

P.O. Box 1049  
Columbus, OH 43216-1049

July 22, 2010

Brian Palmer  
City of Marysville  
125 East Sixth Street  
Marysville, OH 43040

**Re: Storm Water Inspection at Southwest Trunk Sewer Project Phase 1  
Union County  
Permit No: 4GC02982\*AG**

Dear Mr. Palmer:

This letter is written in follow up to a construction storm water inspection by Elizabeth Schaller and Michael Shields of the Ohio EPA, conducted at the Southwest Sewer Project Phase 1 located between Industrial Parkway and the end of the Columbus Metro Equities Parcel on July 13, 2010. The purpose of the inspection was to evaluate compliance with the General Storm Water Permit Associated with Construction Activities. During the inspection, the following items were noted:

It appeared during the inspection that construction activity is completed for this site and all disturbed areas had been permanently stabilized. A Notice of Termination will be required provided the following requirements are met.

- Vegetation must be established sufficient to control erosion which is measured by a minimum vegetative density of 70%.
- A Notice of Termination (NOT) must be submitted once the post construction requirements are verified. The NOT form and filing instructions can be found at: <http://www.epa.state.oh.us/dsw/storm/stormform.aspx>.

If you have any questions regarding this letter or the inspection, please do not hesitate to contact me at our Central District Office at (614) 728-3844.

Sincerely,

Harry Kallipolitis  
Storm Water Coordinator  
Division of Surface Water  
Central District Office

c: Jeff Bohne, Water Quality Supervisor, DSW/CDO

HK/nsm Southwest Trunk Sewer 7-13-10

Ted Strickland, Governor  
Lee Fisher, Lieutenant Governor  
Chris Korleski, Director

