



State of Ohio Environmental Protection Agency

STREET ADDRESS:

Central District Office

MAILING ADDRESS:

Parus Government Center
50 W. Town St., Suite 700
Columbus, Ohio 43215

TELE: (614) 728-3778 FAX: (614) 728-3898
www.epa.state.oh.us

P.O. Box 1049
Columbus, OH 43216-1049

July 22, 2010

Jerry Brems
Licking County
20 South Second Street
Newark, OH 43055

**Re: Construction Storm Water Inspection at ETNA Parkway/ Licking County.
Permit Number: 4GC03129*AG**

Dear Mr. Brems:

This letter is written regarding the storm water inspection; I conducted at **Etna Parkway** located between US 40 & State Route 16 Pataskala, Ohio on July 6, 2010. The Agency understands that these construction activities are currently covered under the General Storm Water Permit Associated with Construction Activities. Based on the site inspection and the General Storm Water Permit, the following items were noted;

Sediment Erosion Controls:

- I observed the recent installation of ditch checks associated with this site.
- Excavated sediment traps in accordance with the storm water permit are expected. During the inspection, I observed a total of three excavated traps.
- Please submit to my attention the revised storm water pollution Prevention Plan addressing location and sizing criteria for each sediment trap associated with this project.

If you have any questions regarding this letter or the inspection, please do not hesitate to call me at our Central District Office at (614) 728-3844 or email at harry.kallipolitis@epa.state.oh.us. In addition, please provide a written response to the action items addressed above within ten days from receipt of this letter. A follow-up inspection will be conducted to ensure the minimum conditions of the General Permit have been met.

Sincerely,

Harry Kallipolitis
Storm Water Coordinator
Division of Surface Water
Central District Office

c: Jeff Bohne, Water Quality Supervisor, DSW/CDO

HK/nsm Etna Parkway 7-6-10

Ted Strickland, Governor
Lee Fisher, Lieutenant Governor
Chris Korleski, Director

