



State of Ohio Environmental Protection Agency

STREET ADDRESS:

Ezarus Government Center
50 W. Town St., Suite 700
Columbus, Ohio 43215

Central District Office

TELE: (614) 728-3778 FAX: (614) 728-3898
www.epa.state.oh.us

MAILING ADDRESS:

P.O. Box 1049
Columbus, OH 43216-1049

July 22, 2010

Rebecca Peterson
Harrisburg Village
1100 Main Street
Harrisburg, OH 43126

**Re: Construction Storm Water Inspection at Village Harrisburg Water Discharge/Waste Water Collection Systems / Franklin County
Permit Number: 4GCD00057*AG**

Dear Ms. Peterson:

This letter is written regarding the storm water inspection conducted by Vinod Tujalpuram and Jed Plank of Ohio EPA at Village Harrisburg Water discharge/ Waste water collection systems located in the Village of Harrisburg, Ohio on July 8, 2010. The agency understands that these construction activities are currently covered under the general storm water permit associated with construction activities. Based on the site inspection and the general storm water permit, the following items were noted;

Drilling Operations:

- During the inspection, we noted the drilling operations under Big Darby Creek. Daily logged inspections of Big Darby Creek are expected concurrent with all drilling operation per your approved FRAC-OUT Contingency Plan.
- An observation of Big Darby Creek entailing the potential of a FRAC-OUT is expected in your logged inspection reports.

If you have any question regarding this letter or the inspection, please do not hesitate to contact me at our Central District Office at (614) 728-3844 or email at harry.kallipolitis@epa.state.oh.us. A follow-up inspection will be conducted to ensure the conditions of the General Permit are met.

Sincerely,

Harry Kallipolitis
Storm Water Coordinator
Division of Surface Water
Central District Office

c: Jeff Bohne, Water Quality Supervisor, DSW/CDO

HK/nsm Village Harrisburg, Water Discharge 7-8-10

Ted Strickland, Governor
Lee Fisher, Lieutenant Governor
Chris Korteski, Director



