



Environmental
Protection Agency

John R. Kasich, Governor
Mary Taylor, Lt. Governor
Scott J. Nally, Director

September 1, 2011

Bob Sidwell
CD Gaming Ventures Inc
825 Berkshire Boulevard
Wyomissing, PA 19610

Re: **Construction Storm Water Inspection at Hollywood Casino / Franklin County**
Permit Number: 4GC03516*AG

Dear Mr. Sidwell,

This letter is written regarding a storm water inspection conducted by Daelann Farnlacher and Lauren Burns of the Ohio EPA at Hollywood Casino located at 200 Georgesville Road Columbus, Ohio on August 15, 2011. The purpose of the inspection was to evaluate compliance with the General Storm Water Permit associated with Construction Activities. During the inspection, our staff noted the following issues associated with construction activities at this site:

Sediment and Erosion Control:

- The dewatering activities associated with retention ponds B1 and B2 require a larger filter bag for sufficient sediment control prior to discharging to the city (see Figure 1).
- The manhole cover and dandy bag noted in Figure 2 have become overburden with sediment. Please take corrective measures to ensure the dandy bag is functioning as intended.
- It was noted that the silt fence, also shown in Figure 2, was installed improperly. Please ensure that all wooden stakes are installed on the opposite side from which it receives heavy sheet flow.

If you have any questions regarding this letter or the inspection, please do not hesitate to contact me at our Central District Office at 614-728-3844 or email at harry.kallipolitis@epa.state.oh.us. In addition, please provide a written response (**email preferred**) to the action items addressed above within ten days from receipt of this letter. A follow-up inspection will be conducted to ensure the minimum conditions of the General Permit have been met.

Sincerely,


Harry Kallipolitis
Storm Water Coordinator
Division of Surface Water
Central District Office

C: Jeff Bohne, Water Quality Supervisor, DSW / CDO

HK/nsm Hollywood Casino 8-15-2011

Central District Office
50 West Town Street, Suite 700
P.O. Box 1049
Columbus, OH 43216-1049

614 | 728 3778
614 | 728 3898 (fax)
www.epa.ohio.gov





Hollywood Casino
Scioto River Watershed
Photo by: Lauren Burns
8-15-11

Figure 1



Figure 2

