



Environmental
Protection Agency

John R. Kasich, Governor
Mary Taylor, Lt. Governor
Scott J. Nally, Director

September 6, 2011

Frank Petruziello
Skilken Pickerington LLC
4270 Morse Road
Columbus, OH 43230

**Re: Construction Storm Water Inspection at Windmill Medical Campus
Fairfield County
Permit Number: 4GC03482*AG**

Dear Mr. Petruziello:

This letter is written regarding a storm water inspection conducted by Daelann Farnlacher of the Ohio EPA at Windmill Medical Campus located at 905 Old Diley Road Pickerington, Ohio on August 11, 2011. The purpose of the inspection was to evaluate compliance with the General Storm Water Permit associated with Construction Activities. During the inspection, our staff noted the following issues associated with construction activities at this site:

Sediment and Erosion Control:

- The concrete washout area requires maintenance.
- The silt fence along the eastern portion of the site requires reinstallation (see Figure 1).
- Be aware the General Permit states that all barren areas which remain idle in excess of 21 days must be protected from erosion within seven days of the last earth disturbing activities. In addition, erosion protection must be implemented for all areas of final grade within seven (7) days.

If you have any questions regarding this letter or the inspection, please do not hesitate to contact me at our Central District Office at 614-728-3844 or email at harry.kallipolitis@epa.state.oh.us. In addition, please provide a written response (**email preferred**) to the action items addressed above within ten days from receipt of this letter. A follow-up inspection will be conducted to ensure the minimum conditions of the General Permit have been met.

Sincerely,

Harry Kallipolitis
Storm Water Coordinator
Division of Surface Water
Central District Office

c: Jeff Bohne, Water Quality Supervisor, DSW / CDO

HK/nsm Windmill Medical Campus 8-11-2011

Central District Office
50 West Town Street, Suite 700
P.O. Box 1049
Columbus, OH 43216-1049

614 | 728 3778
614 | 728 3898 (fax)
www.epa.ohio.gov

