



Environmental
Protection Agency

John R. Kasich, Governor
Mary Taylor, Lt. Governor
Scott J. Nally, Director

September 8, 2011

Mitch Overton
City of Lancaster
1507 East Main Street
Lancaster, OH 43130

Re: Lancaster Multi-use Trail, / Fairfield County

Dear Mr. Overton:

This letter is written regarding the storm water inspection I conducted of the construction activities at the Lancaster Multi-use Trail, located near the River Valley Mall, in Lancaster, Ohio, on August 30, 2011. I understand this site is currently covered under the General Storm Water Permit Associated with Construction Activities. Based on my site inspection and the conditions set forth in the General Permit, the following items must be addressed:

Sediment and Erosion Controls:

There was no active construction during my inspection. The site was stabilized and no erosion appeared to be leaving the site. If construction does start again, please be aware the General Permit states that all barren areas which remain idle in excess of 21 days must be protected from erosion within seven days of the last earth disturbing activities.

If you have any questions regarding this letter or my inspection, please do not hesitate to call me at our Central District Office at (614) 728-3851.

Sincerely,

Gregory L. Sanders
Environmental Specialist
Stormwater Section
Division of Surface Water
Central District Office

c: Jeff Bohne, DSW/CDO

GS/nsm Lancaster Multi-use Trail, August 30, 2011

Central District Office
50 West Town Street, Suite 700
P.O. Box 1049
Columbus, OH 43216-1049

614 | 728 3778
614 | 728 3898 (fax)
www.epa.ohio.gov

