



Environmental  
Protection Agency

John R. Kasich, Governor  
Mary Taylor, Lt. Governor  
Scott J. Nally, Director

August 4, 2011

Steven Legg  
Anchor Cardinal Park Development LLC  
8 E Long Street 3<sup>rd</sup> Floor  
Columbus, OH 43215

**Re: Storm Water Inspection at Anchor Recycling / Franklin County  
Permit Number: 4GC02961\*AG**

Dear Mr. Legg:

This letter is written in follow-up to a construction storm water inspection I conducted at Anchor Recycling located at 453 Claycraft Road Columbus, Ohio on July 27, 2011. The Agency understands these construction activities are currently covered under the General Storm Water Permit Associated with Construction Activities. Based on the site inspection and the General Storm Water Permit, the following items must be addressed:

**Sediment and Erosion Controls:**

- The large centralized basin incorporates a skimmer device to address storm water discharges from the large 48 acre tract. The skimmer does not appear to be functioning as intended. Please maintain the skimmer to ensure it is operating correctly.
- The 18 acre tract located on the southern end of the facility must incorporate sediment ponds per the SWPPP. Previous inspection reports have noted multiple requests to address this issue. As a result, the lack of controls is currently considered a direct violation of your storm water permit.

**Auxiliary Operations:**

- It appears that an asphalt and concrete plant are currently operating at this facility. The SWPPP must be updated accordingly to address these operations.


**Ownership:**

- It appears Anchor Recycling is now ECO Recycling and a permit transfer must be submitted to our attention within seven days of receipt of this letter.

Steven Legg  
Anchor Cardinal Park Development LLC  
Page -2-

If you have any questions regarding this letter or the inspection, please do not hesitate to call me at our Central District Office at (614) 728-3844 or email at [harry.kallipolitis@epa.state.oh.us](mailto:harry.kallipolitis@epa.state.oh.us). In addition, please provide a written response (**email preferred**) to the action items addressed above within ten days from receipt of this letter. A follow-up inspection will be conducted to ensure the minimum conditions of the General Permit have been met.

Sincerely



Harry Kallipolitis  
Storm Water Coordinator  
Division of Surface Water  
Central District Office

c: Jeff Bohne, Water Quality Supervisor, DSW/CDO