



State of Ohio Environmental Protection Agency

STREET ADDRESS:

zarus Government Center
50 W. Town St., Suite 700
Columbus, Ohio 43215

Central District Office

TELE: (614) 728-3778 FAX: (614) 728-3898
www.epa.state.oh.us

MAILING ADDRESS:

P.O. Box 1049
Columbus, OH 43216-1049

July 21, 2010

Storm Water Manager
Target Corporation
PO Box 111
Minneapolis, MN 55440

**Re: Construction Storm Water Inspection at Target-Reynoldsburg, Ohio (T202818)
Fairfield County
Permit Number 4GC02234*AG**

Dear Storm Water Manager:

This letter is written in follow-up to a construction storm water inspection I conducted at 2437 Taylor Park Drive Reynoldsburg, Ohio 43068 on June 21, 2010. The purpose of the inspection was to evaluate compliance with the General Storm Water Permit Associated with Construction Activities. During the inspection, I noted the following issues associated with construction activities at this site:

Post Construction Evaluation:

- The stream bank stabilization of Blacklick Creek appears to be effectively implemented.
- The post construction pond requires maintenance. Based on visual inspection, the outlet structure has become clogged.

If you have any questions regarding this letter or the inspection, please do not hesitate to call me at our Central District Office at (614) 728-3844 or email at harry.kallipolitis@epa.state.oh.us. In addition, please provide a written response to the action items addressed above within ten days from receipt of this letter. A follow-up inspection will be conducted to ensure the minimum conditions of the General Permit have been met.

Sincerely

Harry Kallipolitis
Storm Water Coordinator
Division of Surface Water
Central District Office

c: Jeff Bohne, Water Quality Supervisor, DSW/CDO

HK/nsm Target a Reynoldsburg 6-21-2010

Ted Strickland, Governor
Lee Fisher, Lieutenant Governor
Chris Korleski, Director

