



State of Ohio Environmental Protection Agency

STREET ADDRESS:

Lazarus Government Center
50 W. Town St., Suite 700
Columbus, Ohio 43215

Central District Office

TELE: (614) 728-3778 FAX: (614) 728-3898
www.epa.state.oh.us

MAILING ADDRESS:

P.O. Box 1049
Columbus, OH 43216-1049

July 21, 2010

Bill Franke
Miami Trace Local School District
1400 US Highway 22 Northwest
Washington Court House, Ohio 43160

**Re: Construction Storm Water Inspection at Miami Trace School Campus
Fayette County
Permit Number: 4GC02930 *AG**

Dear Mr. Franke:

This letter is written regarding a storm water inspection conducted by Abigail Tamkin and Stephen Riley of the Ohio EPA at the Miami Trace School Campus located at 3836 State Route 41 Northwest on July 13, 2010. The purpose of the inspection was to evaluate compliance with the General Storm Water Permit Associated with Construction Activities. During the inspection, our staff noted the following issues associated with construction activities at this site:

Sediment and Erosion Control:

- The inlet protections appeared to be in good repair.
- The temporary riser in the sediment detention basin also appeared to be in good repair.
- Please continue to maintain sediment and erosion controls in your self-inspection reports every seven days or within 24 hours of a rain event equal to or greater than 0.5 inches.

Post Construction Requirements:

- The General Storm Water Permit requires specific post construction water quality treatment for all sites. Guidance regarding the post construction requirements is found at: <http://www.epa.state.oh.us/dsw/storm/CGPPCQA.aspx>. Please submit to my attention (email preferred at harry.kallipolitis@epa.state.oh.us) which practice will be installed at this site to ensure compliance with the General Permit. Please include all design criteria and calculations in your submission.

Ted Strickland, Governor
Lee Fisher, Lieutenant Governor
Chris Korleski, Director



Bill Franke
Miami Trace Local School District
Page -2-

If you have any questions regarding this letter or the inspection, please do not hesitate to contact me at our Central District Office at 614-728-3844 or email at: harry.kallipolitis@epa.state.oh.us.

Sincerely,


Harry Kallipolitis
Storm Water Coordinator
Division of Surface Water
Central District Office

c: Jeff Bohne, Water Quality Supervisor, DSW/CDO

HK/nsm Miami Trace School Campus 7-13-2010