



State of Ohio Environmental Protection Agency

STREET ADDRESS:

Lazarus Government Center
50 W. Town St., Suite 700
Columbus, Ohio 43215

Central District Office

TELE: (614) 728-3778 FAX: (614) 728-3898
www.epa.state.oh.us

MAILING ADDRESS:

P.O. Box 1049
Columbus, OH 43216-1049

July 21, 2010

Steven M Mahl
4075 Dixon Road South West
Pataskala, OH 43062

**Re: Storm Water Inspection at 4075 Dixon Road Southwest / Licking County.
Permit No: 4GC02885*AG**

Dear Mr. Mahl:

This letter is written in follow up to a construction storm water inspection, I conducted at **4075 Dixon Road Southwest** located in Pataskala, Ohio on July 12, 2010. The purpose of the inspection was to evaluate compliance with the General Storm Water Permit Associated with Construction Activities. During the inspection, the following items were noted:

It appeared during the inspection that construction activity is completed for this site and all disturbed areas had been permanently stabilized. A Notice of Termination will be required provided the following requirements are met.

- Vegetation must be established sufficient to control erosion which is measured by a minimum vegetative density of 70%.
- A Notice of Termination (NOT) must be submitted once the post construction requirements are verified. The NOT form and filing instructions can be found at: <http://www.epa.state.oh.us/dsw/storm/stormform.aspx>.

If you have any questions regarding this letter or the inspection, please do not hesitate to contact me at our Central District Office at (614) 728-3844.

Sincerely,

Harry Kallipolitis
Storm Water Coordinator
Division of Surface Water
Central District Office

c: Jeff Bohne, Water Quality Supervisor, DSW/CDO

HK/nsm 4075 Dixon Road SW 7-12-10

Ted Strickland, Governor
Lee Fisher, Lieutenant Governor
Chris Korteski, Director



