



State of Ohio Environmental Protection Agency

STREET ADDRESS:

Lazarus Government Center
50 W. Town St., Suite 700
Columbus, Ohio 43215

Central District Office

TELE: (614) 728-3778 FAX: (614) 728-3898
www.epa.state.oh.us

MAILING ADDRESS:

P.O. Box 1049
Columbus, OH 43216-1049

July 19, 2010

Kathy House
City Of Marysville
125 E Sixth St
Marysville, OH 43040

**Re: Construction Storm Water Inspection at City of Marysville WTP
Union County
Permit Number: 4GC02815*AG**

Dear Ms. House:

This letter is written in follow up to a construction storm water inspection by Mike Shields and Lisa Schaller, of the Ohio EPA, conducted at the City of Marysville Water Treatment Plant located at 620 North Main Street in Marysville, Ohio on July 13, 2010. The purpose of the inspection was to evaluate compliance with the General Storm Water Permit Associated with Construction Activities. During the inspection, the following items were noted:

It appeared during the inspection that construction activity is completed for this site and all disturbed areas had been permanently stabilized. A Notice of Termination will be required provided the post construction requirements are met. Please address the following:

- The General Storm Water Permit requires specific post construction water quality treatment for all sites. Guidance regarding the post construction mandates can be found at: <http://www.epa.state.oh.us/dsw/storm/CGPPCQA.aspx>. Please submit to my attention (email preferred at harry.kallipolitis@epa.state.oh.us) which practice will be installed at this site to ensure compliance with the General Permit. Please include all design criteria with your submittal.
- A Notice of Termination (NOT) must be submitted once the post construction requirements are verified. The NOT form and filing instructions can be found at: <http://www.epa.state.oh.us/dsw/storm/stormform.aspx>.


Ted Strickland, Governor
Lee Fisher, Lieutenant Governor
Chris Korleski, Director



Kathy House
City Of Marysville
Page -2-

If you have any questions regarding this letter or the inspection, please do not hesitate to contact me at our Central District Office at (614) 728-3844.

Sincerely,



Harry Kallipolitis
Storm Water Coordinator
Division of Surface Water
Central District Office

c: Jeff Bohne, Water Quality Supervisor, DSW/CDO

HK/nsm Marysville WTP (NOT) 7-13-10