



State of Ohio Environmental Protection Agency

STREET ADDRESS:

Lazarus Government Center
50 W. Town St., Suite 700
Columbus, Ohio 43215

Central District Office

TELE: (614) 728-3778 FAX: (614) 728-3898
www.epa.state.oh.us

MAILING ADDRESS:

P.O. Box 1049
Columbus, OH 43216-1049

July 15, 2010

Clyde Seidle
City of Hilliard
3800 Municipal Way
Hilliard, OH 43026

**Re: Construction Storm Water Inspection at Main Street/Cemetery Road/Scioto-Darby Road
Triangle Project / Franklin County
Permit Number 4GC03254*AG**

Dear Mr. Seidle:

This letter is written in follow-up to a construction storm water inspection conducted by Abigail Tamkin and Elizabeth Schaller of the Ohio EPA at the intersection of Main Street, Cemetery Road and Scioto-Darby Road on July 8, 2010. The purpose of the inspection was to evaluate compliance with the General Storm Water Permit Associated with Construction Activities. During the inspection, our staff noted the following issues associated with construction activities at this site:

Sediment and Erosion Control:

- The installation method for the inlet protection boxes built around existing storm drains do not appear to be adequate to fulfill the terms of your General Permit. Please alter the method of installation to ensure water will not drain underneath the inlet protections, bypassing their sediment control function.

If you have any questions regarding this letter or my inspection, please do not hesitate to contact me at our Central District Office at 614-728-3844 or email at harry.kallipolitis@epa.state.oh.us.

Sincerely,

Harry Kallipolitis
Storm Water Coordinator
Division of Surface Water
Central District Office

c: Jeff Bohne, Water Quality Supervisor, DSW/CDO

HK/nsm Main St. Cemetery Rd Scioto Darby Rd. Triangle Project 7-8-10

Ted Strickland, Governor
Lee Fisher, Lieutenant Governor
Chris Korteski, Director



