



State of Ohio Environmental Protection Agency

**STREET ADDRESS:**

Garus Government Center  
50 W. Town St., Suite 700  
Columbus, Ohio 43215

**Central District Office**

TELE: (614) 728-3778 FAX: (614) 728-3898  
www.epa.state.oh.us

**MAILING ADDRESS:**

P.O. Box 1049  
Columbus, OH 43216-1049

July 13, 2010

Scott Overturf  
Orange Township Board of Trustees  
1680 East Orange Road  
Lewis Center, OH 43035

**Re: Construction Storm Water Inspection at East Orange Road Bike Path Project  
Permit Number 4GC03223\*AG**

Dear Mr. Overturf:

This letter is written in follow-up to a construction storm water inspection conducted by Abigail Tamkin and Vinod Tujalpuram of the Ohio EPA at the Orange Road Bike Path Project at East Orange Road between Abbey Knoll Drive and Bale-Kenyon Road, Lewis Center, Ohio on July 6, 2010. The purpose of the inspection was to evaluate compliance with the General Storm Water Permit Associated with Construction Activities. During the inspection, our staff noted the following issues associated with construction activities at this site:

**Sediment and Erosion Control:**

- The disturbed areas on the north side of East Orange Road appeared void of sediment controls. Please install a perimeter silt fence, or equivalent, to minimize off site sedimentation and ensure compliance with your General Storm Water Permit.

If you have any questions regarding this letter or my inspection, please do not hesitate to contact me at our Central District Office at 614-728-3844 or email at [harry.kallipolitis@epa.state.oh.us](mailto:harry.kallipolitis@epa.state.oh.us).

Sincerely,

Harry Kallipolitis  
Storm Water Coordinator  
Division of Surface Water  
Central District Office

c: Jeff Bohne, Water Quality Supervisor, DSW/CDO

HK/nsm East Orange Road Bike Path Project 7-6-2010

Ted Strickland, Governor  
Lee Fisher, Lieutenant Governor  
Chris Korleski, Director

1960-1961