



State of Ohio Environmental Protection Agency

**STREET ADDRESS:**

W. Zarus Government Center  
50 W. Town St., Suite 700  
Columbus, Ohio 43215

**Central District Office**

TELE: (614) 728-3778 FAX: (614) 728-3898  
www.epa.state.oh.us

**MAILING ADDRESS:**

P.O. Box 1049  
Columbus, OH 43216-1049

July 13, 2010

Mark Tingley  
Buckeye Valley local School District  
901 Coover Road  
Delaware OH 43015

**Re: Construction Storm Water Inspection at Buckeye Valley High School Building  
Permit Number: 4GCO00010\*AG**

Dear Mr. Tingley:

This letter is written regarding the storm water inspection conducted by Vinod Tujalpuram and Abigail Tamkin of Ohio EPA at **Buckeye Valley High School Building Addition & Drive** located on 901 Coover Road, Delaware on July 6, 2010. The Agency understands that these construction activities are currently covered under the General Storm Water Permit Associated with Construction Activities. Based on the site inspection and the General Storm Water Permit, the following items must be addressed;

**Sediment and Erosion Control:**

- The silt fence along the western end of the project has failed and will require maintenance at this time. Corrective measures must be implemented within three days from receipt of this letter
- A huge stock pile was noted on the site and must be seeded and mulch to minimize sediment laden runoff, and ensure compliance with General Storm Water Permit.

**Maintenance:**

- The sediment controls implemented on this site will require maintenance or reinstallation to ensure a proper functioning condition. This general permit states that all sediment controls will be inspected and maintained every seven days or within 24 hours of a precipitation event equal to or greater than 0.5 inches. A log of inspection must be maintained on site for the agency to review.

Ted Strickland, Governor  
Lee Fisher, Lieutenant Governor  
Chris Korleski, Director



**Post Construction Requirements:**

- The General Storm Water Permit requires specific post construction water quality treatment for all sites. Guidance regarding the post construction requirements is found at:  
<http://www.epa.state.oh.us/dsw/storm/CGPPCQA.aspx>. Please submit to my attention (email preferred at [harry.kallipolitis@epa.state.oh.us](mailto:harry.kallipolitis@epa.state.oh.us)) which practice will be installed at this site to ensure compliance with the General Permit. Please include all design criteria and calculations in your submission.

If you have any question regarding this letter or the inspection, please do not hesitate to contact me at our Central District Office at (614) 728-3844 or email at [harry.kallipolitis@epa.state.oh.us](mailto:harry.kallipolitis@epa.state.oh.us). A Follow up inspection will be conducted to ensure the conditions of the General Permit are met.

Sincerely,



Harry Kallipolitis  
Storm Water Coordinator  
Division of Surface Water  
Central District Office