



State of Ohio Environmental Protection Agency

STREET ADDRESS:

W. H. Rouse Caffery
Government Center
50 W. Town St., Suite 700
Columbus, Ohio 43215

Central District Office

TELE: (614) 728-3778 FAX: (614) 728-3898
www.epa.state.oh.us

MAILING ADDRESS:

P.O. Box 1049
Columbus, OH 43216-1049

July 13, 2010

Joe Thomas Junior
Village Communities
470 Olde Worthington Road, Suite 100
Westerville, OH 43082

**Re: Construction Storm Water Inspection at Albany Landings Phase 1, 2 & 3,
Permit Number 4GC02210*AG**

Dear Mr. Thomas:

This letter is written regarding the storm water inspection conducted by Stephen Riley and Vinod Tujalpuram of Ohio EPA at **Albany Landings Phase 1, 2 & 3** located on 4871 Warner Road, Columbus on July 1, 2010. The Agency understands that these construction activities are currently covered under the General Storm Water Permit Associated with Construction Activities. Based on the site inspection and the General Storm Water Permit, the following items must be addressed;

Sediment and Erosion Control

- All barren areas on the southern and eastern end of the project must be protected with perimeter silt fence.
- It has been noted that the sediment pond does not incorporate a sediment control structure such as a temporary riser. All sediment ponds must be modified to address sediment control. Corrective measures are expected within three days from receipt of this letter (figure 1).

Maintenance

- **Maintenance of Controls:** The sediment controls implemented on this site will require maintenance or reinstallation to ensure a proper functioning condition. This general permit states that all sediment controls will be inspected and maintained every seven days or within 24 hours of a precipitation event equal to or greater than 0.5 inches. A log of inspection must be maintained on site for the agency to review.

Ted Strickland, Governor
Lee Fisher, Lieutenant Governor
Chris Korleski, Director

Post Construction Requirements:

- The General Storm Water Permit requires specific post construction water quality treatment for all sites. Guidance regarding the post construction requirements is found at: <http://www.epa.state.oh.us/dsw/storm/CGPPCQA.aspx>. Please submit to my attention (email preferred at harry.kallipolitis@epa.state.oh.us) which practice will be installed at this site to ensure compliance with the General Permit. Please include all design criteria and calculations in your submission.

If you have any questions regarding this letter or the inspection, please do not hesitate to call me at our Central District Office at (614) 728-3844. In addition, please provide a written response to the action items addressed above within ten days from receipt of this letter. A follow-up inspection will be conducted to ensure the minimum conditions of the General Permit have been met.

Sincerely,



Harry Kallipolitis
Storm Water Coordinator
Division of Surface Water
Central District Office

c: Paul Parsons City of Columbus




Figure 1: Sediment pond lacks a riser.

