



State of Ohio Environmental Protection Agency

**STREET ADDRESS:**

Lazarus Government Center  
50 W. Town St., Suite 700  
Columbus, Ohio 43215

**Central District Office**

TELE: (614) 728-3778 FAX: (614) 728-3898  
www.epa.state.oh.us

**MAILING ADDRESS:**

P.O. Box 1049  
Columbus, OH 43216-1049

July 13, 2010

Mike Bashore  
Franklin County Engineers Office  
970 Dublin Road  
Columbus, OH 43215

**Re: Construction Storm Water Inspection at Alum Creek Drive at Groveport Rd. Widening & Traffic S / Franklin County  
Permit Number 4GC03278\*AG**

Dear Mr. Bashore:

This letter is written in follow-up to a construction storm water inspection conducted by Stephen Riley and Elizabeth Schaller of Ohio EPA at Creek at Groveport Road Widening & Traffic S, Groveport, Ohio 43068 on July 6, 2010. The purpose of the inspection was to evaluate compliance with the General Storm Water Permit Associated with Construction Activities. During the inspection, our staff noted the following issues associated with construction activities at this site:

**Sediment and Erosion Control:**

- Sediment and erosion controls are required on the storm drain located east of construction site near Groveport Road (See figure 1).
- Sediment and erosion controls are required on the inlet/outlet leading to the creek running parallel to Alum Creek Drive (See figure 2).
- Sediment and erosion controls are required around any disturbed surface near the creek (See figure 3).
- Please address in your response letter if the appropriate permits have been acquired for the impacts noted to the apparent wetland in photo figure 4.

If you have any questions regarding this letter or my inspection, please do not hesitate to contact me at our Central District Office at 614-728-3844 or email at [harry.kallipolitis@epa.state.oh.us](mailto:harry.kallipolitis@epa.state.oh.us).


Sincerely,

Harry Kallipolitis  
Storm Water Coordinator  
Division of Surface Water  
Central District Office

c: Jeff Bohne, Water Quality Supervisor, DSW/CDO

HK/nsm Alum Creek Dr. at Groveport Rd. Widening & Traffic S  
Ted Strickland, Governor  
Lee Fisher, Lieutenant Governor  
Chris Korteski, Director









Figure 1: Storm drain inlet parallel to Groveport Road



Figure 2: Inlet leading to creek bed




Alum Creek Dr at Groveport Rd Widening and  
Traffic Signal Upgrade  
Big Walnut Creek Watershed

Photo by: Elizabeth Schaller and Stephen Riley  
7-6-10

Note: Ensure protection of wetland within permit  
boundaries



Figure 3: Disturbed area near creek outlet



Alum Creek Dr at Groveport Rd Widening and  
Traffic Signal Upgrade  
Big Walnut Creek Watershed

Photo by: Elizabeth Schaller and Stephen Riley  
7-6-10

Note: Erosion controls necessary to protect  
stream

Figure 4: Wetland disturbance

