



State of Ohio Environmental Protection Agency

STREET ADDRESS:

Central District Office

MAILING ADDRESS:

Lezarus Government Center
50 W. Town St., Suite 700
Columbus, Ohio 43215

TELE: (614) 728-3778 FAX: (614) 728-3898
www.epa.state.oh.us

P.O. Box 1049
Columbus, OH 43216-1049

July 13, 2010

Ron Strussion
Reynoldsburg City School District
7244 East Main Street
Reynoldsburg, OH 43068

**Re: Construction Storm Water Inspection at Rose Hill Elementary School
Franklin County
Permit Number 4GC03257*AG**

Dear Mr. Strussion:

This letter is written in follow-up to a construction storm water inspection conducted by Abigail Tamkin and Elizabeth Schaller of Ohio EPA at Rose Hill Elementary School located at 760 Rose Hill Road in Reynoldsburg, Ohio on July 1, 2010. The purpose of the inspection was to evaluate compliance with the General Storm Water Permit Associated with Construction Activities. During the inspection, our staff noted the following issues:

Sediment and Erosion Control:

- The perimeter silt fence appeared to be in good repair in most areas, however, minor maintenance was apparent on the north side of the project.

If you have any questions regarding this letter or my inspection, please do not hesitate to contact me at our Central District Office at 614-728-3844 or email at harry.kallipolitis@epa.state.oh.us.

Sincerely,

Harry Kallipolitis
Storm Water Coordinator
Division of Surface Water
Central District Office

c: Jeff Bohne, Water Quality Supervisor, DSW/CDO

HK/nsm Rose Hill Elementary School, July 1, 2010

Ted Strickland, Governor
Lee Fisher, Lieutenant Governor
Chris Korleski, Director



