



State of Ohio Environmental Protection Agency

STREET ADDRESS:

Central District Office

MAILING ADDRESS:

Lazarus Government Center
50 W. Town St., Suite 700
Columbus, Ohio 43215

TELE: (614) 728-3778 FAX: (614) 728-3898
www.epa.state.oh.us

P.O. Box 1049
Columbus, OH 43216-1049

July 12, 2010

Matt Weber
City of Delaware
1 S Sandusky Street
Delaware, OH 43015

**Re: Construction Storm Water Inspection at Delaware Hotel / Delaware County
Permit Number: 4GCO00015*AG**

Dear Mr. Weber:

This letter is written in follow-up to a construction storm water inspection conducted by Stephen Riley, Vinod Tujalpuram and Jed Plank of Ohio EPA at Delaware Hotel in Delaware, Ohio on June 30, 2010. The purpose of the inspection was to evaluate compliance with the General Storm Water Permit Associated with Construction Activities. During the inspection, our staff noted the following issues associated with construction activities at this site:

Sediment and Erosion Control:

- There has been sediment disturbance at the entrance to the hotel off of South Sandusky Street (Please refer to photo). Sediment traps must be utilized for areas of concentrated flow and must be sized with a required sediment storage volume per the General Permit. These sediment impoundments will require cleaning once they have exceeded 50 percent of their capacity.

If you have any questions regarding this letter or my inspection, please do not hesitate to contact me at our Central District Office at 614-728-3844 or email at harry.kallipolitis@epa.state.oh.us.


Sincerely,

Harry Kallipolitis
Storm Water Coordinator
Division of Surface Water
Central District Office

c: Jeff Bohne, Water Quality Supervisor, DSW/CDO

HIK/nsm Delaware Hotel

Ted Strickland, Governor
Lee Fisher, Lieutenant Governor
Chris Korleski, Director






Figure 1: South Sandusky Entrance

