

7/12/10

# SIGNATURE RECEIVED

## Ohio EPA

State of Ohio Environmental Protection Agency

STREET ADDRESS:

Lazarus Government Center  
50 W. Town St., Suite 700  
Columbus, Ohio 43215

Central District Office

TELE: (614) 728-3778 FAX: (614) 728-3898  
www.epa.state.oh.us

MAILING ADDRESS:

P.O. Box 1049  
Columbus, OH 43216-1049

**CERTIFIED #91 7108 2133 3932 4449 4579**

July 9, 2010

Julio Valladares  
Gahanna-Jefferson School District  
160 South Hamilton Road  
Gahanna, OH 43230

**Re: Construction Storm Water Inspection at Clark Hall / Franklin County  
Notice of Violation  
Permit Number 4GC03239\*AG**

Dear Mr. Valladares:

This letter is written in follow-up to a construction storm water inspection conducted by Abigail Tamkin and Elizabeth Schaller of Ohio EPA at Clark Hall located at 380 Granville Street in Gahanna, Ohio on June 29, 2010. The purpose of the inspection was to evaluate compliance with the General Storm Water Permit Associated with Construction Activities. During the inspection, our staff noted the following issues associated with construction activities at this site:

**Sediment and Erosion Control:**

- The silt fences on the northern and western perimeter appear to be functioning as intended.
- I understand a sediment pond is currently under construction. Please note that the delay of completion of a functioning sediment pond, or the equivalent, at this stage of construction, is a violation of your Permit. Please ensure the sediment pond is completed and modified for sediment control. In addition, proper perimeter controls are expected for all barren areas.
- The catch basins around the project are currently unprotected. Please install catch basin inlet protections or equivalent to minimize off site sedimentation.


**Post Construction Requirements:**

- The General Storm Water Permit requires specific post construction water quality treatment for all sites. Guidance regarding the post construction requirements is found at: <http://www.epa.state.oh.us/dsw/storm/CGPPCQA.aspx>. Please submit to my attention (email preferred at [harry.kallipolitis@epa.state.oh.us](mailto:harry.kallipolitis@epa.state.oh.us)) which practice will be installed at this site to ensure compliance with the General Permit. Please include all design criteria and calculations in your submission.

Ted Strickland, Governor  
Lee Fisher, Lieutenant Governor  
Chris Korleski, Director

If you have any questions regarding this letter or the inspection, please do not hesitate to call me at our Central District Office at (614) 728-3844 or email at [harry.kallipolitis@epa.state.oh.us](mailto:harry.kallipolitis@epa.state.oh.us). In addition, please provide a written response to the action items addressed above within ten days from receipt of this letter. A follow-up inspection will be conducted to ensure the minimum conditions of the General Permit have been met.

Sincerely,



Harry Kallipolitis  
Storm Water Coordinator  
Division of Surface Water  
Central District Office

c: Jeff Bohne, Water Quality Supervisor, DSW/CDO



## Track & Confirm

### Search Results

Label/Receipt Number: 9171 0821 3339 3244 4945 79  
Class: **First-Class Mail®**  
Service(s): **Return Receipt Electronic**  
Status: **Delivered**

Your item was delivered at 10:22 am on July 12, 2010 in COLUMBUS, OH 43230.

#### Detailed Results:

- **Delivered, July 12, 2010, 10:22 am, COLUMBUS, OH 43230**
- **Notice Left, July 10, 2010, 8:30 am, COLUMBUS, OH 43230**
- **Arrival at Unit, July 10, 2010, 6:22 am, COLUMBUS, OH 43230**
- **Electronic Shipping Info Received, July 09, 2010**

### Notification Options

#### Track & Confirm by email

Get current event information or updates for your item sent to you or others by email. [Go >](#)

#### Return Receipt (Electronic)

Verify who signed for your item by email. [Go >](#)

**Track & Confirm**

Enter Label/Receipt Number.

[Go >](#)



