



State of Ohio Environmental Protection Agency

STREET ADDRESS:

Lazarus Government Center  
50 W. Town St., Suite 700  
Columbus, Ohio 43215

Central District Office

TELE: (614) 728-3778 FAX: (614) 728-3898  
www.epa.state.oh.us

MAILING ADDRESS:

P.O. Box 1049  
Columbus, OH 43216-1049

July 9, 2010

M/I Homes of Central Ohio LLC.  
Jason Francis  
3 Easton Oval Suite 540  
Columbus, OH 43219

**Re: Construction Storm Water Inspection at 5571 Cosgray Road  
Permit No. 4GC03285\*AG**

Dear Mr. Francis:

This letter is written regarding the storm water inspection conducted by Stephen Riley and Vinod Tujalpuram of the Ohio EPA, at the 5571 Cosgray Road Construction Project located on 5571 Cosgray Road in Dublin, Ohio, on June 29, 2010. The Agency understands that these construction activities are currently covered under the General Storm Water Permit Associated with Construction Activities. Based on the site inspection and the General Storm Water Permit, the following items were noted:

**Sediment Erosion Controls:**

- Several barren stock piles were noted during the inspection which must be protected with sediment and erosion controls.
- Please ensure proper erosion protection by seeding the piles with mulch within seven days of receipt of this letter.

If you have any question regarding this letter or the inspection, please do not hesitate to contact me at our Central District Office at (614) 728-3844. A follow-up inspection will be conducted to ensure the conditions of the General Permit are met.

Sincerely,

Harry Kallipolitis  
Storm Water Coordinator  
Division of Surface Water  
Central District Office

c: Jeff Bohne, Water Quality Supervisor, DSW/CDO

HK/nsm 5571 Cosgray Road, Dublin 6-29-10

Ted Strickland, Governor  
Lee Fisher, Lieutenant Governor  
Chris Korleski, Director

