



State of Ohio Environmental Protection Agency

STREET ADDRESS:

**Central District Office**

MAILING ADDRESS:

Lazarus Government Center  
50 W. Town St., Suite 700  
Columbus, Ohio 43215

TELE: (614) 728-3778 FAX: (614) 728-3898  
www.epa.state.oh.us

P.O. Box 1049  
Columbus, OH 43216-1049

July 9, 2010

Matthew B Weber  
City of Delaware  
1 South Sandusky Street  
Delaware, OH 43015

**Re: Construction Storm Water Inspection at US 23 & Peachblow-Winter Relocation / Delaware County: Permit Number 4GCO00020\*AG**

Dear Mr. Weber:

This letter is written in follow-up to a construction storm water inspection I conducted at US Route 23 and Peachblow-Winter Road in Delaware, Ohio on June 23, 2010. The purpose of the inspection was to evaluate compliance with the General Storm Water Permit Associated with Construction Activities. During the inspection, I noted the following issues associated with construction activities at this site:

**Sediment and Erosion Control:**

- The inlet protection directly south of the Career Center is not properly constructed. Please ensure that lateral supports are implemented.
- The southern slope of the tributary to the Olentangy located on the northern end of the project protected immediately.
- Please ensure that all barren areas which remain idle in excess of 21 days are adequately protected.

**Post Construction:**

- I have had the opportunity to evaluate alternatives to the quantity issue for the northern storm water outfall. Based on my conversation with ODOT Central Office, the quantity issue still remains. I will be evaluating alternatives in the future. Please contact me upon receipt to set up meetings to resolve this issue.

If you have any questions regarding this letter or my inspection, please do not hesitate to contact me at our Central District Office at 614-728-3844 or email at [harry.kallipolitis@epa.state.oh.us](mailto:harry.kallipolitis@epa.state.oh.us).

Sincerely,

Harry Kallipolitis  
Storm Water Coordinator  
Division of Surface Water  
Central District Office

c: Jeff Bohne, Water Quality Supervisor, DSW/CDO

HK/nsm US 23 & Peachblow Winter relocation 6-30-10  
Ted Strickland, Governor  
Lee Fisher, Lieutenant Governor  
Chris Korleski, Director



