



State of Ohio Environmental Protection Agency

STREET ADDRESS:

Lazarus Government Center
50 W. Town St., Suite 700
Columbus, Ohio 43215

Central District Office

TELE: (614) 728-3778 FAX: (614) 728-3898
www.epa.state.oh.us

MAILING ADDRESS:

P.O. Box 1049
Columbus, OH 43216-1049

July 9, 2010

Mike Bashore
Franklin County Engineers Office
970 Dublin Road
Columbus, OH 43215

**Re: Construction Storm Water Inspection at Morse Road at Reynoldsburg-New Albany Road
Round-a-Bout / Franklin County
Permit Number 4GC03221*AG**

Dear Mr. Bashore:

This letter is written in follow-up to a construction storm water inspection conducted by Abigail Tamkin and Elizabeth Schaller of Ohio EPA at the Morse Road and Reynoldsburg-New Albany Road Round-a-Bout on June 29, 2010. The purpose of the inspection was to evaluate compliance with the General Storm Water Permit Associated with Construction Activities. During the inspection, our staff noted the following issues associated with construction activities at this site:

Sediment and Erosion Control:

- The silt fence appeared to be functioning adequately; however, sections on the southeast corner of the intersection are in need of repair.
- We noted the alternate method of sediment storage and treatment. Please ensure that all pumping activities do not result in turbid discharges to waters of the state.
- Our staff met with the Franklin County Engineer Staff who indicated barren areas are seeded every Friday, and the required ditch checks will be installed soon.

If you have any questions regarding this letter or my inspection, please do not hesitate to contact me at our Central District Office at 614-728-3844 or email at harry.kallipolitis@epa.state.oh.us.

Sincerely

Harry Kallipolitis
Storm Water Coordinator
Division of Surface Water
Central District Office

c: Jeff Bohne, Water Quality Supervisor, DSW/CDO

HK/hsm Morse Rd. and Reynoldsburg-New Albany Rd. Round about 6-29-10

Ted Strickland, Governor
Lee Fisher, Lieutenant Governor
Chris Korleski, Director

