



State of Ohio Environmental Protection Agency

STREET ADDRESS:

Lazarus Government Center
50 W. Town St., Suite 700
Columbus, Ohio 43215

Central District Office

TELE: (614) 728-3778 FAX: (614) 728-3898
www.epa.state.oh.us

MAILING ADDRESS:

P.O. Box 1049
Columbus, OH 43216-1049

July 9, 2010

Chad Moorehead
Thirty-One Company Real Estate LLC
231 Commerce Blvd.
Johnstown, OH 43031

**Re: Construction Storm Water Inspection at Thirty-One Company/ Licking County
Permit Number 4GC03273*AG**

Dear Mr. Moorehead:

This letter is written in follow-up to a construction storm water inspection conducted by Elizabeth Schaller and Abigail Tamkin of the Ohio EPA at Thirty-One Company in Johnstown, Ohio on June 29, 2010. The purpose of the inspection was to evaluate compliance with the General Storm Water Permit Associated with Construction Activities. The following issues were noted:

Sediment and Erosion Control:

- The majority of the silt fence was properly installed in order to reduce off-site sediment transport. The silt fence southwest of the wetland has failed and will require maintenance at this time.
- The outlet riser on sediment pond appears to be clogged with algae and requires immediate attention. See attached photo.

If you have any questions regarding this letter or my inspection, please do not hesitate to contact me at our Central District Office at 614-728-3844 or email at harry.kallipolitis@epa.state.oh.us.

Sincerely,

Harry Kallipolitis
Storm Water Coordinator
Division of Surface Water
Central District Office


Enclosure

c: Jeff Bohne, Water Quality Supervisor, DSW/CDO

HK/nsm Thirty One Company 6-20-10

Ted Strickland, Governor
Lee Fisher, Lieutenant Governor
Chris Korleski, Director





Thirty-One Company
Elking River Watershed

Photo by: Elizabeth Schaller and Abigail Tamkin
6-29-10

Note: Sediment pond outlet appears to be
clogged by algae.




Figure 1: Clogged outlet requires immediate attention

