



State of Ohio Environmental Protection Agency

STREET ADDRESS:

Lazarus Government Center
50 W. Town St., Suite 700
Columbus, Ohio 43215

Central District Office

TELE: (614) 728-3778 FAX: (614) 728-3898
www.epa.state.oh.us

MAILING ADDRESS:

P.O. Box 1049
Columbus, OH 43216-1049

July 8, 2010

Steve Phillips
Oxbow River & Stream Restoration Inc.
2905 Klondike Road
Delaware, OH 43015

**Re: Construction Storm Water Inspection at Clover Groff Run Stream Restoration Project, Delaware County.
Permit Number 4GCD00029*AG**

Dear Mr. Phillips:

This letter is written in follow-up to a construction storm water inspection I conducted at Clover Groff Run Stream Restoration Project located in Scioto and Darby Creek Road Hilliard, Ohio 43026 on June 24, 2010. The purpose of the inspection was to evaluate compliance with the General Storm Water Permit Associated with Construction Activities. During the inspection, I noted the following issues associated with construction activities at this site:

Sediment and Erosion Control:

- The western edge of the project, adjacent to the housing complex, was void of sediment controls. To ensure compliance with General Permit, please install perimeter controls immediately.
- Be aware the General Permit states that all barren areas which remain idle in excess of 21 days must be protected from erosion within seven days of the last earth disturbing activities. In addition, erosion protection must be implemented for all areas of final grade within seven (7) days.

If you have any questions regarding this letter or my inspection, please do not hesitate to contact me at our Central District Office at 614-728-3844 or email at harry.kallipolitis@epa.state.oh.us.

Sincerely,

Harry Kallipolitis
Storm Water Coordinator
Division of Surface Water
Central District Office

c: Jeff Bohne, Water Quality Supervisor, DSW/CDO

HK/nsm Clover Groff Stream Restoration 6-24-10

Ted Strickland, Governor
Lee Fisher, Lieutenant Governor
Chris Koreski, Director



