



State of Ohio Environmental Protection Agency

**STREET ADDRESS:**

Lazarus Government Center  
50 W. Town St., Suite 700  
Columbus, Ohio 43215

**Central District Office**

TELE: (614) 728-3778 FAX: (614) 728-3898  
www.epa.state.oh.us

**MAILING ADDRESS:**

P.O. Box 1049  
Columbus, OH 43216-1049

July 8, 2010

Brad Jones  
ODOT, District 6  
400 East William Street  
Delaware, OH 43015

**Re: Storm Water Inspection at Hard Road Improvements, Columbus.  
Permit Number 4GC01714\*AG**

Dear Mr. Jones:

This letter is written regarding the storm water inspection that I conducted at Hard Road Improvements, located in Columbus, Ohio, on June 23, 2010. The Agency understands that these construction activities are currently covered under the General Storm Water Permit. Based on the site inspection and the General Storm Water Permit, the following items must be addressed:

**Sediment and Erosion Controls:**

- Perimeter control adjacent to State Route 315 is necessary for proper sediment control.
- Please continue inlet protection maintenance.
- Stockpiles along Hard Road appear to have been idle more than 21 days. Proper erosion control is required.

If you have any question(s) regarding this letter or the inspection, please do not hesitate to contact me at our Central District Office at (614) 728-3844. Follow-up inspections will be conducted to ensure the conditions of the General Permit are continuing to be met.

Sincerely,

Harry Kallipolitis  
Storm Water Coordinator  
Division of Surface Water  
Central District Office

c: Jeff Bohne, Water Quality Supervisor, DSW/CDO  
Brad McLaughlin

HK/nsm Hard Road Improvement 6-23-10

Ted Strickland, Governor  
Lee Fisher, Lieutenant Governor  
Chris Korteski, Director



