



State of Ohio Environmental Protection Agency

STREET ADDRESS:

Lazarus Government Center
50 W. Town St., Suite 700
Columbus, Ohio 43215

Central District Office

TELE: (614) 728-3778 FAX: (614) 728-3898
www.epa.state.oh.us

MAILING ADDRESS:

P.O. Box 1049
Columbus, OH 43216-1049

July 8, 2010

Roger McClain
51 North Third Street Suite 701
Newark, OH 43055

**Re: Construction Storm Water Inspection at The Inn at Olentangy Trail
Delaware County
Permit No 4GCO00018*AG**

Dear Mr. McClain:

This letter is written in follow-up to a construction storm water inspection I conducted at The Inn at Olentangy Trail at the Intersection of U.S. Route 23 and Corduroy Drive on June 23, 2010. The purpose of the inspection was to evaluate compliance with the General Storm Water Permit Associated with Construction Activities. During the inspection, I noted the following issues associated with construction activities at this site:

Sediment and Erosion Control:

- Based on my knowledge of the Storm Water Pollution Prevention Plan, a sediment pond was planned for the site. There appeared to be no sediment control pond on the project site. Please address the issue in order to comply with the permit.
- A silt fence must be installed on the northeast side of the project near the culvert under U.S. Route 23.
- The silt fence along the north side of the project, bordering the Delaware County Library construction site, needs repaired to adequately control sediment.

If you have any questions regarding this letter or my inspection, please do not hesitate to contact me at our Central District Office at 614-728-3844 or email at harry.kallipolitis@epa.state.oh.us.

Sincerely

Harry Kallipolitis
Storm Water Coordinator
Division of Surface Water
Central District Office

c: Jeff Bohne, Water Quality Supervisor

HK/nsm The Inn at Olentangy Trail 6-23-10

Ted Strickland, Governor
Lee Fisher, Lieutenant Governor
Chris Korleski, Director



