



State of Ohio Environmental Protection Agency

**STREET ADDRESS:**

Lazarus Government Center  
50 W. Town St., Suite 700  
Columbus, Ohio 43215

**Central District Office**

TELE: (614) 728-3778 FAX: (614) 728-3898  
www.epa.state.oh.us

**MAILING ADDRESS:**

P.O. Box 1049  
Columbus, OH 43216-1049

July 8, 2010

Robert M Riley  
Delaware Count Engineers Office  
50 Channing Street  
Delaware, OH 43015

**Re: Construction Storm Water Inspection at Porter Central Road Del-Tr12-0.00  
Permit Number 4GC03241\*AG**

Dear Mr. Riley:

This letter is written in follow-up to a construction storm water inspection conducted by Abigail Tamkin and Elizabeth Schaller at the Intersection of Centerburg Road and Porter Central Road in Sunbury, Ohio on June 28, 2010. The purpose of the inspection was to evaluate compliance with the General Storm Water Permit Associated with Construction Activities. During the inspection, the following items were noted:

**Sediment and Erosion Control:**

- The ditch checks alone are not sufficient to meet the criteria of the permit. In line sediment traps are necessary to ensure full compliance. (See Figure 1)
- Corrective measures must be taken to ensure pump around provisions concurrent with all in-stream activities.
- During the inspection, our inspection staff noted the illicit dumping of concrete washout water near and adjacent to the stream. Corrective measures must be taken to ensure a concrete washout area is established that will not threaten waters of the state. (See Figure 2)

If you have any questions regarding this letter or my inspection, please do not hesitate to contact me at our Central District Office at 614-728-3844 or email at [harry.kallipolitis@epa.state.oh.us](mailto:harry.kallipolitis@epa.state.oh.us).

Sincerely,

Harry Kallipolitis  
Storm Water Coordinator  
Division of Surface Water  
Central District Office

HK/nsm Centerburg Rd and Porter Central Rd. 6-28-10

Ted Strickland, Governor  
Lee Fisher, Lieutenant Governor  
Chris Korleski, Director



