



State of Ohio Environmental Protection Agency

STREET ADDRESS:

Central District Office

MAILING ADDRESS:

Lazarus Government Center
50 W. Town St., Suite 700
Columbus, Ohio 43215

TELE: (614) 728-3778 FAX: (614) 728-3898
www.epa.state.oh.us

P.O. Box 1049
Columbus, OH 43216-1049

June 30, 2010

Charles Driscoll
Nelson Farms
Associates Incorporated
495 S High St #150
Columbus, OH 43215

**Re: Construction Storm Water Inspection at Nelson Farms Sections One, Two, & Three /
Delaware County: Permit Number 4GC01352*AG**

Dear Mr. Driscoll:

This letter is written in follow-up to a construction storm water inspection I conducted at Nelson Farms in Delaware County on June 23, 2010. The purpose of the inspection was to evaluate compliance with the General Storm Water Permit Associated with Construction Activities. During the inspection, I noted the following issues associated with construction activities at this site:

Sediment and Erosion Control:

- The sediment pond has exceeded its design capacity and must be cleared out.
- The outlet riser must be re-wrapped with silt fence.
- There was a dark blue substance found in the pond on the extreme southeast corner. Please evaluate the origin of this substance and remediate if necessary.

If you have any questions regarding this letter or the inspection, please do not hesitate to call me at our Central District Office at (614) 728-3844 or email at harry.kallipolitis@epa.state.oh.us.

In addition, please provide a written response to the action items addressed above within ten days from receipt of this letter. A follow-up inspection will be conducted to ensure the minimum conditions of the General Permit have been met.

Sincerely,

Harry Kallipolitis
Storm Water Coordinator
Division of Surface Water
Central District Office

HK/nsm Nelson Farms Section 1,2,and 3

Ted Strickland, Governor
Lee Fisher, Lieutenant Governor
Chris Korieski, Director

