



State of Ohio Environmental Protection Agency

STREET ADDRESS:

Lazarus Government Center
50 W. Town St., Suite 700
Columbus, Ohio 43215

Central District Office

TELE: (614) 728-3778 FAX: (614) 728-3888
www.epa.state.oh.us

MAILING ADDRESS:

P.O. Box 1049
Columbus, OH 43216-1049

June 30, 2010

Bob Pruchnicki
10265 Brecksville Rd
Brecksville, OH 44141

**Re: Construction Storm Water Inspection at Wheaton Village / Licking County
Permit Number 4GC01517*AG**

Dear Mr. Pruchnicki:

This letter is written in follow-up to a construction storm water inspection I conducted at Wheaton Village in Reynoldsburg on June 21, 2010. The purpose of the inspection was to evaluate compliance with the General Storm Water Permit Associated with Construction Activities. During the inspection, I noted the following issues associated with construction activities at this site:

Sediment and Erosion Control:

- There appears to be no drainage outlet in the sediment pond.

Please address your financial status, to ensure continued compliance with you General Storm Water Permit.

If you have any questions regarding this letter or my inspection, please do not hesitate to contact me at our Central District Office at 614-728-3844 or email at harry.kallipolitis@epa.state.oh.us.

Sincerely,

Harry Kallipolitis
Storm Water Coordinator
Division of Surface Water
Central District Office

c: Jeff Bohne, Water Quality Supervisor

.HK/nsm Wheaton village 6-21-2010

Ted Strickland, Governor
Lee Fisher, Lieutenant Governor
Chris Korleski, Director

