OhioEPA

State of Ohio Environmental Protection Agency

STREET ADDRESS:
Lazarus Government Center
50 W. Town St., Suite 700
Columbus, Ohio 43215

Central District Office

TELE: (614) 728-3778 FAX: (614) 728-3898
www.epa.state.oh.us

MAILING ADDRESS:
P.O. Box 1049
Columbus, OH 43216-1049

June 30, 2010

Stephen Renner
Franklin County Commissioners
Sanitary Engineering Department
280 East Broad Street
Columbus, OH 43215

Re: Darbydale WWTP / Franklin County

Dear Mr. Renner:

This letter is written regarding the storm water inspection that I conducted at the Darbydale WWTP construction site along Lambert Road between Darbydale WWTP and Timberlake WTP, in Franklin County on June 23, 2010. **It appears construction has not started at this site.** I understand that these construction activities are currently covered under the General Storm Water Permit Associated with Construction Activities. Based on the site inspection and the General Storm Water Permit, the following items must be addressed:

Sediment and Erosion Controls:

There did not appear to be any construction activity at the site. The site was stabilized and no erosion was leaving the site. Please be aware that if construction activities commence that the General Permit mandates that all barren areas which remain idle areas in excess of 21 days be protected from erosion (i.e., seed and straw), within seven days from the last construction activity.

If you have any questions regarding this letter or the inspection, please do not hesitate to call me at our Central District Office at (614) 728-3851.

Sincerely,

Gregory L. Sanders
Environmental Specialist
Division of Surface Water
Central District Office

c: Jeff Bohne, Water Quality Supervisor, DSW/CDO

GLS/nsm Darbydale WWTP, June 23, 2010