



State of Ohio Environmental Protection Agency

STREET ADDRESS:

zarus Government Center
50 W. Town St., Suite 700
Columbus, Ohio 43215

Central District Office

TELE: (614) 728-3778 FAX: (614) 728-3898
www.epa.state.oh.us

MAILING ADDRESS:

P.O. Box 1049
Columbus, OH 43216-1049

June 24, 2010

John Geller
City of Heath
1287 Hebron Road
Heath, OH 43056

**Re: Construction Storm Water Inspection at David Shai House:
Permit Number: 4GC03063*AG**

Dear Mr. Geller:

This letter is written in follow-up to a construction storm water inspection I conducted at located at Newark, Ohio on May 26, 2010. The purpose of the inspection was to evaluate compliance with the General Storm Water Permit Associated with Construction Activities. During the inspection, I noted the following issues associated with construction activities at this site:

Sediment and Erosion Controls:

- The perimeter controls associated with this site must be maintained. I noted several areas of failed silt fence at the eastern perimeter of the site which require immediate attention.
- The permit mandate final seeding within 7 days after achieving final grade.
- Self inspection logs must be maintained onsite available for review.
- Inspections of the site must be conducted every 7 days or within 24 hrs of rainfall greater than 0.5 inches to ensure compliance with general permit requirements.

Post Construction Requirements:

- The General Storm Water Permit requires specific post construction water quality treatment for all sites. Guidance regarding the post construction requirements is found at: <http://www.epa.state.oh.us/dsw/storm/CGPPCQA.aspx>. Please submit to my attention (email preferred at harry.kallipolitis@epa.state.oh.us) which practice will be installed at this site to ensure compliance with the General Permit. Please include all design criteria and calculations in your submission.

Ted Strickland, Governor
Lee Fisher, Lieutenant Governor
Chris Korleski, Director

John Geller
City of Heath
Page 2

Please demonstrate your post construction requirements will be met (see attachment). Please be able to demonstrate your post construction mandates per the General Permit are met (see attachment)

If you have any questions regarding this letter or my inspection, please do not hesitate to contact me at our Central District Office at 614-728-3844 or email at harry.kallipolitis@epa.state.oh.us.

Sincerely,



Harry Kallipolitis
Storm Water Coordinator
Division of Surface Water
Central District Office

HK/nsm David Shai House 310 Central Pkwy 5-26-10