



State of Ohio Environmental Protection Agency

STREET ADDRESS:

Central District Office

MAILING ADDRESS:

Lazarus Government Center
50 W. Town St., Suite 700
Columbus, Ohio 43215

TELE: (614) 728-3778 FAX: (614) 728-3898
www.epa.state.oh.us

P.O. Box 1049
Columbus, OH 43216-1049

June 21, 2010

Keith Coleman
Pizzuti Development Inc.
Two Miranova Place #800
Columbus, OH 43215

Re: Creekside 9-11, Franklin County

Dear Mr. Coleman:

This letter is written regarding the storm water inspection I conducted on June 16, 2010, of the construction activities at Creekside 9-11 located near the intersection of Rohr Road and Creekside Parkway, in Obetz, Ohio. The Agency understands that these construction activities are currently covered under the General Storm Water Permit Associated with Construction Activities. Based on the site inspection and the General Storm Water Permit, the following was observed or discussed at the site:

Sediment and Erosion Controls:

The site did not have any active construction. No erosion appeared to be leaving the site and the site appeared to be in compliance with the General Storm Water Permit. The site had been stabilized. However, there are still a lot of weeds growing at the site that does not promote good stabilization. The site drains to two sediment ponds. Please continue to maintain the site and re-seed if areas start to erode or fugitive dust becomes an issue.

If you have any questions regarding this letter or my inspection, please do not hesitate to call me at our Central District Office at (614) 728-3851.


Sincerely,

Gregory L. Sanders
Environmental Specialist
Division of Surface Water
Central District Office

c: Jeff Bohne, Water Quality Supervisor, DSW/CDO

GLS/nsm Creekside 9-11, June 16, 2010

Ted Strickland, Governor
Lee Fisher, Lieutenant Governor
Chris Korteski, Director



Creekside
Stabilize stockpiles
Big Walnut Creek Watershed
June 16, 2010
Photo by: Greg Sanders

